

Intl memo no 918-001 - QS - Aux B - Work Completion Report

Company	Crescentia labs	Name of contractor	Nani babu	SI No. site bills reg.	364		
Project/site	IGV	Nature of work	Erraction	Dt. site bills reg.	17-07-2024		
Block no		Work done from date	07.07.2024	M-codex bill ID.			
WO no		Work done to date	12-07-2024	WO issued ?			
WO date		Contractor bill no		GST bill required?			
Sl. No.	Unit/floor	Details of work	Qty	Units	Rate ID	Rate	Amount
1	Two 1500kva DG Shifting and	DG-1 with isolator alignment and fixing rubber pads	16	Ton	EL205/EL206	750+250	16,000
2	alignment placing isolator panel to busduct	DG-2 with isolator alignment and fixing rubber pads	16	Ton	EL205/EL206	750+250	16,000
3							
4							
5							
6							
7							
8							
9							
10							
<b>TOTAL AMOUNT</b>							<b>32,000</b>
Remarks: Work Completed							
Approved by project manager		Approved by OS team		Approved by Director/E&D team			
Sign: <i>V. Ramkrishna Reddy</i>		Sign:		Sign:			
Date: 18/7/24		Date:		Date:			

ESTIMATE SHEET						
Company Name:	cresecentia			Approved By	Ramesh reddy	
Project:	Gv1			Sign:		
Work Description:	Two 1500kva DG Shifting and alignment placing isolater panel to busduct					
Contractor:	Nani babu					
Prepared By:	Akhil					
Date:	29-06-2024 to 02-07-2024					
S No.	Item Head	Item Description	Quantity	Units	Rate	Amount
1	Two 1500kva DG Shifting and alignment placing isolater	DG-1 with isolator alignment and fixing rubber pads	16.00	Ton	750+250	16,000
2	panel to busduct	DG-2 with isolator alignment and fixing rubber pads	16.00	Ton	750+250	16,000
<b>TOTAL AMOUNT</b>						<b>32,000</b>

**MEASUREMENT SHEET**

Company Name:	cresecentia			Approved	Ramesh reddy				
Project	Gv1			Sign:					
Work Description	Two 1500kva DG Shifting and placing isolator panel to busduct								
Contractor	Nani babu								
Prepared By	Akhil								
Date	29-06-2024 to 02-07-2024								
			A	B	C	D	E	F	
<b>S No.</b>	<b>Item Head</b>	<b>Item Description</b>	<b>Length</b>	<b>Width</b>	<b>Height</b>	<b>Nos</b>	<b>Quantity</b>	<b>Units</b>	
1	Two 1500kva DG Shifting and alignment placing isolator panel to busduct	DG-1 with isolator alignment and fixing rubber pads	1.00	1.00	1.00	1.00	16.00	Ton	
2		DG-2 with isolator alignment and fixing rubber pads	1.00	1.00	1.00	1.00	16.00	Ton	