



- GENERAL NOTES**
- USE M25 (1:1.5:2) GRADE CONCRETE FOR COLUMNS & M20 (1:1.5:3) FOR BEAMS & SLAB
 - USE FE415 GRADE STEEL
 - PROVIDE CLEAR COVER OF 1.5" FOR COLUMNS, 1" FOR BEAMS & 3/4" FOR SLAB
 - PROVIDE 1" CAMBER AT FREE END FOR CANTILEVER BEAMS & SLABS.
 - IN SLAB EXTEND -VE STEEL UP TO 0.30L FROM FACE OF SUPPORT.
 - DO NOT PROVIDE EXTRA REINFORCEMENT AT SIMPLY SUPPORTS.
 - LAP LENGTH 48 D (D - IS THE DIA OF THE BAR) IN COMPRESSION.
 - LAP LENGTH 52 D (D - IS THE DIA OF THE BAR) IN TENSION.
 - ONLY FIGURED DIMENSIONS SHALL BE FOLLOWED.
 - ALL THE DIMENSIONS ARE IN INCHES & FEET.
 - DO NOT SCALE THE DRAWING.
 - REFER ARCHITECT DRAWING FOR CENTER LINE DIMENSIONS.

GOOD FOR CONSTRUCTION

Architects & Engineers:
KULKARNI CONSULTANTS
 STRUTURAL ENGINEERS, ARCHITECTS & PROJECT CONSULTANTS
 #216, KUBERA TOWERS, NARAYAN GUDA, HOBBARANKI,
 CONTACT NOS:- (0823232891, 09246343724, 09246343728,
 E-mail: info@modiproperties.com

**5-4-187 / 3&4, Soham manohar, IT Floor,
 M.G. Road, Secunderabad-500003,
 Ph: 0823232891, 09246343724, 09246343728,
 E-mail: info@modiproperties.com**

Owners & Developers:
 VISTA HOMES BLOCK - (F)

SCALE: NTS
DATE: 15-10-13
DRAWN: PMWN
CHECKED: KULKARNI
APPROVED: KULKARNI

TITLE: TYPICAL BEAM SECTION DETAILS
DWG. NO.: KC/H/SD/F/
REV. NO.: 0

REV. NO.	DESCRIPTION	DATE
1		