



SCHEDULE OF SLABS				
SLAB MARK	THICKNESS	TYPE	REINFORCEMENT STEEL AT	
			SHORT SPAN	LONG SPAN
S1	5"	+	8Ø @ 6" C/C	8Ø @ 8" C/C
S2	5"	-	8Ø @ 6" C/C	8Ø @ 8" C/C
S3	5"	+	8Ø @ 7" C/C	8Ø @ 7" C/C
S4	5"	-	10Ø @ 6" C/C	8Ø @ 8" C/C

- General Notes : --
- Use M25 (1:1:2) grade for columns & M20 (1:1.5:3) for footings, slab & Beams
 - Use FE 500 grade tor steel.
 - Provide clear cover of 2" for footings & 1.5" for columns.
 - S.B.C of the Soil is taken as 250kn/m2.
 - Footings are designen for Ground & Upeer 2 floor.
 - Provide clear cover of 1"for beams
 - Read horizontal beams from left to right & vertical from bottom to left.
 - crank +ve bars at L/4 th of span & extend -ve bars L/5 th of span.
 - Do not over lap bottom rods at center and top rods at support.
 - Slab thickness

DESCRIPTION	DATE
GOOD FOR CONSTRUCTIONS	



Client	MODI PROPERTIES & INVESTMENTS PVT.LTD
Project	NILAGIRI ESTATE PHASE - II
STRUCTURAL CONSULTANT	KULKARNI CONSULTANT'S STRUCTURAL ENGINEERS, ARCHITECTS & PROJECT CONSULTANT'S #216, KUBERA TOWER'S, NARAYAN GUDA, HYDERABAD. CONTACT NO'S:- 04023223891, 09246343724, 09246343720.

DATE	10-11-2017	TYPE	AA2 (DOUBLE)
DEALT BY	PAWAN	TITLE	FIRST FLOOR SLAB DETAILS
DESIGN BY	SRIKANTH	DWG. NO.	KC/SD/NS2/2A
CHECKED & APPROVED	KULKARNI	REV. No.	1