



**BORE WELL STATUS :**

BORE WELL NO'S :	DEPTH	STATUS	YIELD OF WATER	PUMP DEPTH	PUMP CAPACITY	CONNECTION TO OHT pipe Dia.
BORE WELL NO. 1	400 ft.	Working	Not Good	300 ft.	3 HP / 3 Phase	Connected to sump (1 1/4" Dia)
BORE WELL NO. 2	200 ft.	Working	Average	180 ft.	3 HP / 3 Phase	Connected to sump (1 1/4" Dia)
BORE WELL NO. 3	400 ft.	Working	Good	350 ft.	3 HP / 3 Phase	Connected to sump (1 1/4" Dia)
BORE WELL NO. 4	300 ft.	Working	Average	250 ft.	3 HP / 3 Phase	Connected to sump (1 1/4" Dia)
BORE WELL NO. 5	400 ft.	Not Working	Average	350 ft.	3 HP / 3 Phase	Connected to sump (1 1/4" Dia)

NOTE : NO OHT, NO RO Plant only Sump Capacity : 2,00,000 ltrs.

**APPROVED BY**  
**17 JUL 2019**  
**SOHAM MODI**  
**MANAGING DIRECTOR**

Description	Direction	Owners & Developers :	Date :	16.07.2019	Promoted by
BORE POINTS DETAILS PLAN		Modi Properties & Investments Pvt.Ltd.	Prepared By :	Triveni	Modi Properties & Investments Pvt. Ltd. Phone:+91-40-66335551
		Project Name & Phase :	Approved By :	Soham Modi	
		Serene Farms	Scale :	N.T.S	