


- GENERAL NOTES**
- USE M25 (1:1.5:2) GRADE CONCRETE FOR COLUMNS & M20 (1:1.5:3) FOR BEAMS & SLAB
  - USE FE 500 GRADE TOR STEEL.
  - PROVIDE CLEAR COVER OF 1.5" FOR COLUMNS, 1" FOR BEAMS & 3/4" FOR SLAB
  - PROVIDE 1" CAMBER AT FREE END FOR CANTILEVER BEAMS & SLABS.
  - IN SLAB EXTEND -VE STEEL UPTO 0.30L FROM FACE OF SUPPORT.
  - DO NOT PROVIDE EXTRA REINFORCEMENT AT SIMPLY SUPPORTS.
  - LAP LENGTH 48 D (D- IS THE DIA OF THE BAR) IN COMPRESSION.
  - LAP LENGTH 52 D (D- IS THE DIA OF THE BAR) IN TENSION.
  - ONLY FIGURED DIMENSIONS SHALL BE FOLLOWED.
  - ALL THE DIMENSIONS ARE IN INCHES & FEET.
  - DO NOT SCALE THE DRAWING.
  - REFER ARCHITECT DRAWING FOR CENTER LINE DIMENSIONS.

REV. No.	DESCRIPTION	DATE
1		



Owners & Developers: \_\_\_\_\_

5-4-187 /3&4, Soham mansion, II Floor, M.G. Road, Secunderabad-500003. Phone:66335551(4lines) Fax:040-27544058 E-mail :info @modiproperties.com

Architects & Engineers: **KULKARNI CONSULTANT'S**  
 STRUCTURAL ENGINEERS, ARCHITECTS & PROJECT CONSULTANT'S  
 #216, KUBERA TOWER'S, NARAYAN GUDA, HYDERABAD.  
 CONTACT NO'S:- 04023223891, 09246343724, 09246343720.

SCALE:	N.T.S	VISTA HOMES BLOCK - (E)
DATE:	01-07-2019	TITLE: RAMP BEAM DETAILS
DRAWN:	SANISH	DWG. NO. KC/VH/SD/C/9
CHECKED & APPROVED:	KULKARNI	SH. NO-4 REV. No. 0