


- GENERAL NOTES**
- USE M25 (1:1.5:2) GRADE CONCRETE FOR COLUMNS & M20 (1:1.5:3) FOR BEAMS & SLAB
  - USE FE415 GRADE TOR STEEL.
  - PROVIDE CLEAR COVER OF 1.5" FOR COLUMNS , 1" FOR BEAMS & 3/4" FOR SLAB
  - PROVIDE 1" CAMBER AT FREE END FOR CANTILEVER BEAMS & SLABS.
  - IN SLAB EXTEND -VE STEEL UPTO 0.30L FROM FACE OF SUPPORT.
  - DO NOT PROVIDE EXTRA REINFORCEMENT AT SIMPLY SUPPORTS.
  - LAP LENGTH 48 D ( D-IS THE DIA OF THE BAR) IN COMPRESSION.
  - LAP LENGTH 52 D ( D-IS THE DIA OF THE BAR) IN TENSION.
  - ONLY FIGURED DIMENSIONS SHALL BE FOLLOWED.
  - ALL THE DIMENSIONS ARE IN INCHES & FEET.
  - DO NOT SCALE THE DRAWING.
  - REFER ARCHITECT DRAWING FOR CENTER LINE DIMENSIONS.



<b>Owners &amp; Developers:</b>  <b>KULKARNI CONSULTANTS</b> STRUCTURAL ENGINEERS, ARCHITECTS & PROJECT CONSULTANTS #216, KUBERA TOWERS, NARAYAN GUWA, HYDERABAD, INDIA. CONTACT NO: 9849323591, 9246532323, 9246532323 E-mail: info@noidaprojects.com	
<b>Architects &amp; Engineers:</b> M.G. Reddy/Sudhakar-500002, P. Srinivas/Chimes/ Pkx0407/2544058 E-mail: info@noidaprojects.com	
<b>SCALE:</b> N.T.S. <b>DATE:</b> 25-11-13 <b>DRAWN:</b> PAVAN <b>CHECKED:</b> KULKARNI <b>APPROVED:</b>	<b>TITLE:</b> VISTA HOMES BLOCK - (G) <b>CELLAR BEAM DETAILS</b>
<b>DWG. NO.:</b> KC/HH/SD/5/9 <b>REV. NO.:</b> 0	<b>SH. NO.3</b> <b>REV. NO.</b>