## Quality Control Check Repot. Stage: After Plastcring (Apartments)

-Flat No.	R-811	Other	(	Sl. No.	27623
Company	Dro or I	Project	ATR	Phase	1
Prepared by	H Con Svidler	Sign	10	Date	41/42/12
Project Manager	K. SHI ERIH	Sign	2	Date	41/20/61
Previous stage report no.	no.	87393	Report filed and signed by PM?	ed by PM?	Yes No
Checked By MD on		MD Sign		For filling	☐Yes ☐No
Recommendation:  Stop further work  Stop further work  Proceed with furt  Proceed with furt	Recommendation:  Stop further work. Submit ATR on QC report to QC team. Proceed only after recheck by QC.  Stop further work. Proceed with work after submitting ATR on QC report to QC team.  Proceed with further work only after making corrections pointed out in the QC report. ATR not required.  Proceed with further work. ATR not required.	eport to QC team. Proc fter submitting ATR or king corrections pointe uired.	xeed only after recheck 1 QC report to QC team 1 out in the QC report.	by QC. L ATR not required.	

Inspection should be done after:

- brickwork & 2 coats plastering is completed
- after cleaning the apartment.
- water proofing, screeding in bathrooms is completed.
- before starting painting, tiling & flooring.

## Plastering Check.

Notes:

- Mark v for correct or minor mistake which does not require correction
- Mark X for minor mistake that requires minor correction.
- Mark XX for major mistake that requires correction by replacement or re-fixing. Mark XXX for major mistake that cannot be corrected.
- 9"unplastered area from SFL should be left including in common areas and terraces.
- Windows must be checked with templates. Plastering must be 3mm margin for luppum work. Tolerance 1/2".
- Provision of tiles in bathrooms, kitchen & wash areas (rough plastering). Check size of sink bowl. Hole should be 1" to 2" larger. (Tolerance: 1")
- All doors frames should have 1/2" grooves.
- Sill top must be of uniform thickness, correct height, at one level & without broken edges.