Quality Control Check Repot. Stage: After Plastering (Apartments)

Danamandation
Checked By MD on MD Sign For filling Yes No

Inspection should be done after:

- brickwork & 2 coats plastering is completed
- after cleaning the apartment.
- water proofing, screeding in bathrooms is completed.
- before starting painting, tiling & flooring.

Plastering Check.

- Mark ✓ for correct or minor mistake which does not require correction
- Mark \times for minor mistake that requires minor correction.
- Mark XX for major mistake that requires correction by replacement or re-fixing.
- Mark XXX for major mistake that cannot be corrected.

 9"unplastered area from SFL should be left including in common areas and terraces.
- Windows must be checked with templates. Plastering must be 3mm margin for luppum work. Tolerance 1/2".
- Provision of tiles in bathrooms, kitchen & wash areas (rough plastering). Check size of sink bowl. Hole should be 1" to 2" larger. (Tolerance: 1")
- All doors frames should have 1/2" grooves.
- Sill top must be of uniform thickness, correct height, at one level & without broken edges.