Flat No.	0-626	Other		SI. No.	2996m3
Company	(C)	Project	1) mr - 11	Phase	(=)
Prepared by	P. S. Kumor Sign	Sign	Produ	Date	81/49/80
Project Manager	K. ghowh Kumon Sign	Sign	als.	Date	81/20/20
Previous stage report no.	no.	28125	Report filed and signed by	d by PM?	Yes No
Checked By MD on		MD Sign		For filling	Yes No
Recommendation: Stop further work. Stop further work. Proceed with furth	Recommendation: Stop further work. Submit ATR on QC report to QC team. Proceed only after recheck by QC. Stop further work. Proceed with work after submitting ATR on QC report to QC team. Proceed with further work only after making corrections pointed out in the QC report. ATR n Proceed with further work. ATR not required.	eport to QC team. Proce ter submitting ATR on ting corrections pointed ired.	eed only after recheck? QC report to QC team! I out in the QC report.	by QC. ATR not required.	

Inspection should be done after:

- brickwork & 2 coats plastering is completed
- after cleaning the apartment.
- water proofing, screeding in bathrooms is completed.
- before starting painting, tiling & flooring.

Plastering Check.

- Mark \vee for correct or minor mistake which does not require correction Mark \times for minor mistake that requires minor correction.
- Mark XX for major mistake that requires correction by replacement or re-fixing.
- Mark XXX for major mistake that cannot be corrected.
- 9"unplastered area from SFL should be left including in common areas and terraces.
 Windows must be checked with templates. Plastering must be 3mm margin for luppum work. Tolerance 1/4".
- Provision of tiles in bathrooms, kitchen & wash areas (rough plastering). Check size of sink bowl. Hole should be 1" to 2" larger. (Tolerance: 1")
- All doors frames should have 1/2" grooves.
- Sill top must be of uniform thickness, correct height, at one level & without broken edges.