	Quality Control Check Repot.		Stage: Before Casting Plinth	nth Beam (Villas)	
Block No	42	1		Sl. No.	30496
Company	Severa Censharya Project		Severa Povery Ph	Phase)
Prepared by	S. Sunch town			Date	12/6/18
Project Manager	Sanwar.	Sign	Seful gelow Sorman	Date	12/6/18
Previous stage report no.	39563		Report filed and signed by PM?		∠Yes □No
Checked By MD on	MD Sign	gn		For filling	☐ Yes ☐ No
Recommendation: Stop further work. Submit ATR on QC report Stop further work. Proceed with work after su Proceed with further work only after making of Proceed with further work. ATR not required.	ecommendation: Stop further work. Submit ATR on QC report to QC team. Proceed only after recheck by QC. Stop further work. Proceed with work after submitting ATR on QC report to QC team. Proceed with further work only after making corrections pointed out in the QC report. ATR not required. Proceed with further work. ATR not required.	QC team. Proce nitting ATR on or rections pointed	ed only after recheck be QC report to QC team. out in the QC report.	y QC. ATR not required.	

Plinth Beam Check.

Notes:

- Inspection should be done before casting of plinth beam.
 Yellow enumel paint to be used for marking FFL of flooring. Mark 2° above FFL on column steel. Plinth beam top must be 2°3" (in case of pavers) or 2°4" (in case of RCC slab) below the mark Prepare plinth beam. Dimensions Check Plan as follows:

- U1 44
- a Show outer dimensions. (Tolerance 2")
 b Show length and width of plinth beams (Tolerance 1")
 c Print an A3 size plan
 Circle each correct dimension with green colour. Circle each incorrect dimension with red colour and mention actual dimension next to it.

 Project managers must make pedestal/column 0 self-check report similar to report for column check. QC must collect report and attach the same to this report.

	٦	
THE PARTY OF THE P	linth Beam Dimensions Check Plan enclosed?	
	✓Yes □No	

Quality Control Check Repot. Stage: Before Casting Plinth Beam (Villas)

Quality of centering, rod bending and concreting.	
Quality of centering, rod bending and concreting?	Good Avg. Bad
Have rods for staircase slab been provided?	☐Yes ☐No
Quality of Bracing Provided?	☐ Good ☐ Avg. ☐ Bad
Alignment of beams on outer side?	☐ Good ☐ Avg. ☐ Bad
Brackets for elevation features provided?	□Yes □No □NA
Level marking at 2' above FFL is made?	∑Yes □No
Column steel overlapping and cranking? (overlapping length should be 45 to 50 D)	☐Correct ☐ Needs correction
Pedestal/column0 - self check report attached?	☐Yes ☐No
Remarks:	

Plinth Beam Steel check.

- Mark v for correct or minor mistake which does not require correction

 Mark x for minor mistake that requires minor correction.

 Mark x x for major mistake that requires correction by replacement or re-fixing.

 Mark x x for major mistake that cannot be corrected.
- Columns overlapping length should be 45 to 50 D.

Quality Control Check Repot. Stage: Before Casting Plinth Beam (Villas)

Remarks:	7.	6.	5.	4.	3.	2.		S No
	Depth and width of beams	Covering blocks for beams	Steel Check - Beams Bearing	Steel Check - Beams Overlapping & Cranking	Steel Check - Beams Extra Bars	Steel Check - Beam size of bars,	Steel Check - Beam no of rods	Item
	5	ζ,	<	ς	ζ	ζ	(Quantitative Check (• or ×)
	☐ Good ☑ Avg. ☐ Bad	☐ Good ☑ Avg. ☐ Bad	☐ Good ☐ Avg. ☐ Bad	☐ Good ☑ Avg. ☐ Bad	Good Avg. Bad	☐ Good ☐ Avg. ☐ Bad	Good Avg. Bad	Qualitative Check (Good / Avg. / Bad)