## Quality Control Check Repot. Stage: Before Casting Plinth Beam (Villas)

Block No Company Prepared by Project Manager	Project Project Sign  Oalamuralikushun Sign	Bloomdade Phase Pridy Date  Opposite Date	2/8/18 2/8/18
Project Manager	Oalamuredikustun Sign		
Previous stage report no.	29612	Report filed and signed by PM?	
Checked By MD on	MD Sign	For 1	For filling Ycs No
Recommendation:  Stop further work. Submit ATR on QC report Stop further work. Proceed with work after s  Proceed with further work only after making of the proceed with further work. ATR not required.	ecommendation:  Stop further work. Submit ATR on QC report to QC team. Proceed only after recheck by QC Stop further work. Proceed with work after submitting ATR on QC report to QC team.  Proceed with further work only after making corrections pointed out in the QC report. ATR not required.	roceed only after recheck by QC on QC report to QC team. inted out in the QC report. ATR	by QC.  ATR not required.

## Plinth Beam Check.

Notes:

- Inspection should be done before easting of plinth beam
  Yellow enamel point to be used for marking FFL of flooring. Mark 2' above FFL on column steel. Plinth beam top must be 2'3" (in case of pavers) or 2'4" (in case of RCC slab) below the mark Prepare plinth beam. Dimensions (Tolerance 2')
  Show outer dimensions (Tolerance 2'')
  Show length and width of plinth beams (Tolerance 1'')
  e. Print an A3 NZe plan
  Circle each correct dimension with green colour. Circle each incorrect dimension with red colour and mention actual dimension next to it.
  Project managers must make pedestal column 0 self check report similar to report for column check. QC must collect report and attach the same to this report.

Plinth Beam Dimensions Check Plan enclosed? V Yes □ No

## Quality Control Check Repot. Stage: Before Casting Plinth Beam (Villas)

		('olumn steel overlapping and cranking? (overlapping length should be 45 to 50 D)	Brackets for elevation features provided? ☐ Yes ☐ No ☐ YÑA	Alignment of beams on outer side?	Quality of Bracing Provided?	Have rods for staircase slab been provided?	Quality of centering, rod bending and concreting?	Quality of centering, rod bending and concreting.
--	--	---	--	-----------------------------------	------------------------------	---	---	---

Plinth Beam Steel check.

Zoles:

- Mark v for correct or minor mistake which does not require correction
   Mark X for minor mistake that requires minor correction.
   Mark X Y for major mistake that requires correction by replacement or re-fixing.
   Mark X X for major mistake that cannot be corrected.
   Columns overlapping length should be 45 to 50 D.

## Quality Control Check Repot. Stage: Before Casting Plinth Beam (Villas)

Remarks	7.	6.	5.	4.	3.	2.	<b>,</b>	s No
-	Depth and width of beams	Covering blocks for beams	Steel Check - Beams Bearing	Steel Check - Beams Overlapping & Cranking	Steel Check - Beams Extra Bars	Steel Check - Beam size of bars	Steel Check - Beam no of rods	Item
		۲,		< <		۷,	2	Quantitative Check (✓ or 🗙)
	Rood Avg. Bad	Good Avg. Bad	☑ Good ☐ Avg. ☐ Bad	☐Good ☐ Avg. ☐ Bad	MGood Myg. MBad	YGood ☐ Avg. ☐ Bad	Good Avg. Bad	Qualitative Check (Good / Avg. / Bad)