

Quality Control Check Report. Stage: Before Casting Plinth Beam (Villas)

Block No	05	Project	Blom Dale	SI. No.	31545
Company	KNM	Sign	P. Sain Kumar	Phase	
Prepared by	P. Sain Kumar	Date	24/9/18		
Inspector	Belamwadi Krishna				
	30340				

Proceed with further work. ATR not required.

Plinth Beam Check.

Notes:

1. The concrete strength of the plinth beam is to be checked by the contractor before casting. The test results must be attached to this report.

2. The contractor must ensure that the plinth beam is cast on a firm and level base.

Yes No

Quality Control Check Report Stage: Before Casting Plinth Beam (Villas)

<u>Quality of centering, rod bending and concreting.</u>	<input type="checkbox"/> Good <input checked="" type="checkbox"/> Avg. <input type="checkbox"/> Bad
<u>Quality of centering, rod bending and concreting?</u>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
<u>Have rods of reinforcement slab been provided?</u>	<input type="checkbox"/> Good <input checked="" type="checkbox"/> Avg. <input type="checkbox"/> Bad
<u>Quality of Slab provided?</u>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
<u>Slab reinforcement provided?</u>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
<u>Level of column above plinth is made?</u>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
<u>Remarks:</u>	✓
	✓

Plinth Beam Steel check.

Notes:

1. Mark ✓ for correct or minor mistake which does not require correction
2. Mark ✗ for minor mistake that requires minor correction.
3. Mark ✗✗ for major mistake that requires correction by replacement or re-fixing.
4. Mark ✗✗✗ for major mistake that cannot be corrected.
5. Columns overlapping length should be 45 to 50 D.

Quality Control Check Repot. Stage: Before Casting Plinth Beam (Villas)

S No	Item	Quantitative Check (✓ or X)	Qualitative Check (Good / Avg. / Bad)
1.	Steel Check - Beam no of bars	✓	<input checked="" type="checkbox"/> Good <input type="checkbox"/> Avg. <input type="checkbox"/> Bad
2.	Good	✓	<input checked="" type="checkbox"/> Good <input type="checkbox"/> Avg. <input type="checkbox"/> Bad
3.	Good	✓	<input checked="" type="checkbox"/> Good <input type="checkbox"/> Avg. <input type="checkbox"/> Bad
4.	Good	✓	<input checked="" type="checkbox"/> Good <input type="checkbox"/> Avg. <input type="checkbox"/> Bad
5.	Good	✓	<input checked="" type="checkbox"/> Good <input type="checkbox"/> Avg. <input type="checkbox"/> Bad
6.	Good	✓	<input checked="" type="checkbox"/> Good <input type="checkbox"/> Avg. <input type="checkbox"/> Bad
7.	Good	✓	<input checked="" type="checkbox"/> Good <input type="checkbox"/> Avg. <input type="checkbox"/> Bad

Remarks:
