Quality Control Check Repot. Stage: Before Casting Plinth Beam (Villas)

Recommendation: Stop further work. Submit ATR on QC report to QC team. Proceed only after recheck by QC. Stop further work. Proceed with work after submitting ATR on QC report to QC team. Proceed with further work only after making corrections pointed out in the QC report. ATR not required. Proceed with further work. ATR not required.	Checked By MD on	Previous stage report no.	Project Manager	Prepared by	Company	Block No
	MD Sign	14408	A. Swesh Sign	V. Sanketh Sign	Voc CLIP) Project	127 -
beed only after recheck In QC report to QC team dout in the QC report.		Report filed and signed by PM?	(Jan	V. Sukryl	Voc	
by QC. ATR not required.	For filling	ed by PM?	Date	Date	Phase	SI. No.
	☐ Yes ☐ No	MYes □No	25-08-18	25-09-18	١	31265

Plinth Beam Check.

Notes:

- Inspection should be done before easting of plinth beam.
 Yellow enamel paint to be used for marking FFL of flooring. Mark 2° above FFL on column steel. Plinth beam top must be 2°3" (in case of pavers) or 2°4" (in case of RCC slab) below the mark Prepare plinth beam. Dimensions Check Plan as follows:

 a. Show outer dimensions (Tolerance 2°)
 b. Show length and width of plinth beams (Tolerance 1°)
 c. Print an A3 size plan.
 Circle each correct dimension with green colour. Circle each incorrect dimension with red colour and mention actual dimension next to it.

Plinth Beam Dimensions Check Plan enclosed?	5. Project managers must make pedestal column 0 self check report similar to report for column check. QC must collect report and attach the same to this report
	port

Quality Control Check Repot. Stage: Before Casting Plinth Beam (Villas)

Ouality of centering, rod bending and concreting.	
Quality of centering, rod bending and concreting?	Good Avg. Bad
Have rods for staircase slab been provided?	Yes No
Quality of Bracing Provided?	☐ Good ¶Ayg. ☐ Bad
Alignment of beams on outer side?	Good Avg. Bad
Brackets for elevation features provided?	
Level marking at 2' above FFL is made?	Yes No
Column steel overlapping and cranking? (overlapping length should be 45 to 50 D)	Correct Needs correction
Pedestal/column0 – self check report attached?	Yes No
Remarks:	

Plinth Beam Steel check.

Notes:

- Mark v for correct or minor mistake which does not require correction
 Mark X for minor mistake that requires minor correction.
 Mark X x for major mistake that requires correction by replacement or re-fixing.
 Mark X X ior major mistake that cannot be corrected.
 Columns overlapping length should be 45 to 50 D.

Quality Control Check Repot. Stage: Before Casting Plinth Beam (Villas)

Remarks:	7.	6.	5.	4.	ω.	2.	1	S No
	Depth and width of beams	Covering blocks for beams	Steel Check - Beams Bearing	Steel Check - Beams Overlapping & Cranking	Steel Check - Beams Extra Bars	Steel Check - Beam size of bars	Steel Check - Beam no of rods	Item
	~	<u> </u>	. 🗸	~	√	~	~	Quantitative Check (• or ×)
	Good Avg. Bad	Good Avg. Bad	Good Nvg. Bad	Good V Avg. Bad	Good Avg. Bad	Good Avg. Bad	Good Avg. Bad	Qualitative Check (Good / Avg. / Bad)