	Quality Control Check Repot.		Stage: Before Casting Plinth 1	nth Beam (Villas)	
Block No	126			Sl. No.	2535
Company	pleym ente	Project	Allen entes	Phase	鬥
Prepared by	Pfs kun	Sign	CFINE	Date	411415
Project Manager	Rodrentzam	Sign	Charl	Date	21417
Previous stage report no.	26593		Report filed and signed by PM?	PM?	∯Ýes □No
Checked By MD on		MD Sign		For filling	☐ Yes ☐ No
Recommendation: Stop further work. Submit ATR on QC report Stop further work. Proceed with work after su Proceed with further work only after making of the proceed with further work. ATR not required.	commendation: Stop further work. Submit ATR on QC report to QC team. Proceed only after recheck Stop further work. Proceed with work after submitting ATR on QC report to QC team. Proceed with further work only after making corrections pointed out in the QC report. Proceed with further work. ATR not required.	OC team. Pritting ATR octions poin	Stop further work. Submit ATR on QC report to QC team. Proceed only after recheck by QC. Stop further work. Proceed with work after submitting ATR on QC report to QC team. Proceed with further work only after making corrections pointed out in the QC report. ATR not required. Proceed with further work. ATR not required.	C. not required.	

Plinth Beam Check.

Notes:

- Inspection should be done before easting of plinth beam.

 Yellow enamel paint to be used for marking FFL of flooring. Mark 2' above FFL on column steel. Plinth beam top must be 2'3" (in case of pavers) or 2'4" (in case of RCC slab) below the mark. Prepare plinth beam Dimensions Check Plan as follows:

 a. Show outer dimensions. (Tolerance 2")

- **.** 5
- b. Show length and width of plinth beams (Tolerance 1")
 c. Print an A3 size plan.
 Circle each correct dimension with green colour. Circle cach incorrect dimension with red colour and mention actual dimension next to it.

	Plinth Beam Dimensions Check Plan enclosed?	
The state of the s		

Quality Control Check Repot. Stage: Before Casting Plinth Beam (Villas)

Remarks:	Column steel overlapping and cranking? (overlapping length should be 45 to 50 D)		Brackets for elevation features provided?	Alignment of beams on outer side?	Quality of Bracing Provided?	een provided?	Quality of centering, rod bending and concreting?	Quality of centering, rod bending and concreting.
	✓ Correct Needs correction	YYes No	□Yes □No ☑ÑA	☐ Good WAvg. ☐ Bad	☐ Good ☑ Avg. ☐ Bad	Yes Mo	☐ Good ☐ Avg. ☐ Bad	

Plinth Beam Steel check.

Notes:

- Mark v for correct or minor mistake which does not require correction
 Mark X for minor mistake that requires minor correction.
 Mark XX for major mistake that requires correction by replacement or re-fixing.
 Mark XXX for major mistake that cannot be corrected.
 Columns overlapping length should be 45 to 50 D.

Quality Control Check Repot. Stage: Before Casting Plinth Beam (Villas)

Remarks:	7.	6.	5.	4.	ω.	2.	1	S No
	Depth and width of beams	Covering blocks for beams	Steel Check - Beams Bearing	Steel Check - Beams Overlapping & Cranking	Steel Check - Beams Extra Bars	Steel Check - Beam size of bars	Steel Check - Beam no of rods	Item ^
	<	<	<	< ·				Quantitative Check (• or *)
	Good ☐ Avg. ☐ Bad	Good Avg. Bad	✓ Good ☐ Avg. ☐ Bad	✓ Good Avg. Bad	Good Avg. Bad	☐ Good ☐ Avg. ☐ Bad	Good Avg. Bad	Qualitative Check (Good / Avg. / Bad)