

Block No. 218 Column No. 01 Sl. No. 32168

Company VDC (LLP) Project VDC Phase -

Prepared by S. Kuldeep Date 24/11/18

Project Manager A. Suresh Site 31825 Inspected by S. Kuldeep Date 24/11/18

Prepared stage report no. 31825 Report final signed by VDC Date 24/11/18

Checked by ATN Date 24/11/18 Inspected by VDC Date 24/11/18

Remarks: Stop further work. Proceed with work after submitting ATN on civil report to civil team.

Proceed with further work after submitting ATN on civil report to civil team.

Proceed with further work. ATN not required.

Columns Position Check

Notes:

1. Inspection should be done after casting of columns at each stage and before starting centering works for each slab.

2. Prepare Columns Position Check Plan as follows:

- a. Divide blocks into smaller sub-blocks.
- b. Show size and orientation of columns. (Tolerance 0.5")
- c. Show inner -- inner space between columns. (Tolerance 1")
- d. Show diagonals for 20° of bays. (Tolerance 1.5")
- e. Print an A3 size plan.

3. Circle each correct dimension with green colour. Circle each incorrect dimension with red colour and mention actual dimension next to it.

Columns Position Check Plan enclosed?  Yes  No

Slab Dimensions Check

Notes:

1. Prepare Slab (or plinth beams) Dimensions Check Plan as follows:

- a. Show outer dimensions of slab. (Tolerance 2")
- b. Show length and width of balconies. (Tolerance 1")
- c. Show inner dimensions for columns and for wall. (Tolerance 2")
- d. Print an A3 size plan.

2. Circle each correct dimension with green colour. Circle each incorrect dimension with red colour and mention actual dimension next to it.

Slab Dimensions Check Plan enclosed?  Yes  No N/A

Specify thickness of slab? Actual thickness of slab

Quality of concrete, roof, foundation and waterproofing?  
 (Quality of structure and foundation and waterproofing?)

Quality of materials?

Quality of workmanship?

Are the piping materials of the correct material?

Number of repairs from any piping, foundation, roof or waterproofing?

Have cracks been found for roof, walls and slab around and number of floor joists?

Remarks:

Good  Avg.  Bad

Good  Avg.  Bad

Good  Avg.  Bad

Good  Avg.  Bad

Good  Avg.  Bad

**Curing**

Bricks for curbing made on site?

Bund size is less than 100 sqft?

Drum (200 lbs) provided for curing?

Gunny bags used for column curing?

Distance of tap from furthest distance that requires curing. (max permitted 100')

Frequency of curing in number of times a day (inquire from laborers)

Is the pressure in the curing pipe more than 15' head?

Quality of infrastructure for curing.

Remarks:

Yes  No  N/A

Yes  No

Yes  No

Yes  No

20'-6"

2 times

Yes  No

Good  Avg.  Bad

4. Check height, grade, level & level marking sheet.

1. Check for the correct or incorrect grade which does not require correction.
2. Mark the position of the location of the correction.
3. Sign, Mark & record the correction.
4. Check for the correct or incorrect grade which does not require correction.
5. Mark the position of the location of the correction.
6. Sign, Mark & record the correction.

No.	Particulars	Spec.	Actual	No. of	Survey	Homogeneity	Height	Area	Reference
1.	A1	C1	8'-4"	8'-5"	✓	✓	✓	✓	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
2.	A3	C3	8'-4"	8'-4"	✓	✓	✓	✓	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
3.	A4	C1	8'-3"	8'-6"	✓	✓	✓	✓	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
4.	B1	C1	8'-4"	8'-3"	✓	✓	✓	✓	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
5.	B3	C3	Stair	Stair	✓	✓	✓	✓	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
6.	B4	C4	8'-3"	8'-6"	✓	✓	✓	✓	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
7.	C1	C2	8'-4"	8'-3"	✓	✓	✓	✓	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
8.	C3	C3	Stair	Stair	✓	✓	✓	✓	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
9.	C4	C2	8'-1"	8'-0"	✓	✓	✓	✓	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
10.	D1	C2	8'-4"	8'-2"	✓	✓	✓	✓	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
11.	E2	C3	8'-4"	8'-2"	✓	✓	✓	✓	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
12.	E4	C1	8'-3"	8'-6"	✓	✓	✓	✓	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
13.									Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
14.									Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
15.									Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
16.									Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
17.									Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
18.									Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
19.									Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
20.									Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>