

S No	Room	Wall thickness (✓ or X)	Beds in walls (✓ or X)	Chicken mesh (✓ or X)	External brickwork & beam joint (✓ or X)	Room Dimensions (✓ or X)	Room Dimensions Difference in inches	Diagonal (✓ or X)	Diagonal Difference in inches	Balcony sill level (✓ or X)	Room Height (✓ or X)	Plumb of walls (Good/Avg./Bad)	Alignment of beams and walls - Nos.
1	Bedroom 1 M. Bed	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
2	Toilet 1 M. Toi	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
3	Bedroom 2 G. Bed	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
4	Toilet 2 C. Toi	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
5	Bedroom 3 M. Bed	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
6	Toilet 3 G. Bed	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
7	Bedroom 4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
8	Toilet 4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
9	Drawling	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
10	Dining	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
11	Lobby 1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
12	Lobby 2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
13	Terrace / balcony 1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
14	Terrace / balcony 2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
15	Head room	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
16	Portico	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
17	Kitchen	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
18	Utility	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1
19	Other	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	1

Remarks: ^{For} M. Bed 23, G. Bed 23 & G. Bed walls instead of 4" they are constructed 6" thick level Bed's properly not laid.