

vitro labs

TEST REPORT

2-2-647/A/3&4, 3rd Floor,
 Karur Vysya Bank Building,
 Shivam Road, Hyderabad-500 013.
Phone : 040-27421389
Fax : 040-27423582
e-mail : labsvitro@yahoo.com

Issued to : M/s.	M/s. May Floor Heights Sy.No. 1/1, 2/1/1 & 191 (P), Mallapur, Uppal (M)	Ref. No. : VL/W/R/05/2006
		Date : 03.11.2006
		Your Ref. :
		Receipt on : 02.11.2006

Sample Particulars :	Water
-----------------------------	--------------


TEST RESULTS

Desirable Potable Limits
(as per IS : 10500)

S.No.	Characteristics	Values	Value
1.	pH	7.87	6.50 – 8.50
2.	Electrical Conductivity (micro mhos)	952	---
3.	Dissolved solids (mg/l)	574	<500
4.	Total Hardness as CaCO ₃ (mg/l)	384	<300
5.	Alkalinity to methylorange as CaCO ₃ (mg/l)	Nil	---
6.	Alkalinity to methylorange as CaCO ₃ (mg/l)	200	<200
7.	Non-Carbonate hardness as CaCO ₃ (mg/l)	184	---
8.	Calcium as CaCO ₃ (mg/l)	280	<187
9.	Magnesium as CaCO ₃ (mg/l)	104	123
10.	Sodium as CaCO ₃ (mg/l)	90	---
11.	Potassium as CaCO ₃ (mg/l)	02	---
12.	Chloride as CaCO ₃ (mg/l)	180	<352
13.	Sulphate as CaCO ₃ (mg/l)	93	<208
14.	Nitrate as CaCO ₃ (mg/l)	03	<36
15.	Fluoride as F (mg/l)	1.34	<1.00
16.	Silica as SiO ₂ (mg/l)	09	---
17.	Iron as Fe (mg/l)	Nil	<0.3
18.	Colour	Colourless	<5.0
19.	Turbidity (NTU)	1.30	<5.0

Sample not drawn by us.

Authorised Signatory



Offers analytical services for Environmental, Water, Industrial Effluents, Ores & Minerals, Ferrous & Non-Ferrous Alloys, Petroleum Products, Food Materials, Soils, Poultry Feeds & Rice Bran, Etc.

Environmental Consultants & Analytical Chemists