



From:  
The Dy. Chief Electrical Inspector to  
Government, Hyderabad,  
H.NO.1-8-499/10,Chikkadpally,  
Hyderabad - 500 020.  
Phone No.27664512

To:  
M/s Modi Properties & Investments  
Private Limited  
Greenwood Residency  
Sy.No.202-207(P)  
Block- C., Kaukoor, Yapral  
Ranga Reddy District.

Lr.No.Dy. CEIG/HYD/MSB/D.No. 215 /2010 dated 3 -02-2010.

Sir,

Sub: - The Electricity Act, 2003 and Indian Electricity Rules-1956 - Multistoried Building of M/s Modi Properties & Investments Private Limited Greenwood Residency Sy.No.202-207(P) Block- C., Kaukoor, Yapral Ranga Reddy - Statutory Approval under Rule 50-A of Indian Electricity Rules 1956 - Accorded.

Ref: - 1) Inspection Dated: 02/01/2010  
2) This office Letter No: Dy. CEIG/Hyd/MSB/D.No:CAMP/09dt: 02/01/2010  
3) Management letter dated 3 /2/2010

\*\*\*

Under Rule 50-A of the Indian Electricity Rules, 1956, the following equipment of your Multistoried Building are approved for energisation.

S.No.	Equipment	Make	Maker's S.No.	Capacity	Voltage
<b>I.</b>	<b>M.V.Installation:</b>				
	1. Lift motor (5Nos x 5HP)	--	--	25HP	440 V
	2. Borewell motor	--	--	05HP	440 V
<b>II.</b>	<b>L.V.Installation:</b>				
	1. Total Flats 50Nos x 05KW			250KW	230V
	2. Common Load			02KW	230V

Any additions or alterations to existing installation shall not be connected to supply unless and until such alterations or additions have been approved in writing by the Dy. Chief Electrical Inspector to Government, Hyderabad Under Rule 63(3) of the Indian Electricity Rules, 1956.

Under Rules 30 (4), 46 (3) and 65(7) of the Indian Electricity Rules, 1956, you are at all times be solely responsible for the maintenance of the above installation in such condition as to be free from danger.

Yours faithfully,

  
**DY. CHIEF ELECTRICAL INSPECTOR TO  
GOVERNMENT, HYDERABAD.**

Copy to the Divisional Engineer/Operation/APCPDCL/ Medchal, Ranga Reddy District. For information and energisation of MSB