FIRE PREVENTION WING

From
Public Information Officer
Fire Prevention Wing,
GHMC, Hyderabad

To Sri Soham Modi, # 5-4-187/3 & 4, II Floor, Soham Mansion, M.G.Road, Secunderabad – 500003. Ph: 040-6633551/2/3.

RC.NO:16/RTI/AD/FPW/GHMC/2016, DATED: 29.08.2016.

SUB: Greater Hyderabad Municipal Corporation – Fire Prevention Wing – Your Request under under RTI Act, 2005 seeking clarification regarding requirement of Fire NOC to your building – Information Provided – Regarding.

REF:

- 1. Your letter under Right to Information Act, 2005, Dated: 23.08.2016.
- 2. Fire NOC issued vide Rc.No.689/AD/FPW/GHMC/2012 Dated: 17.07.2012.

*** **** ***

Vide reference cited 1st, we are informed that you have obtained Provisional Fire NOC for the Club House from Fire Prevention wing, GHMC vide reference cited 2nd for M/s. Vista Homes in the land bearing Sy.Nos. 193,194 & 195, Situated in Kapra Village, Keesara Mandal, Ranga Reddy District.

The floor wise details as given by you and the Occupancy of each floor is follows.

S1. No.	Floor	Purpose as given by you	Occupancy as per NBC of India.
1.	Ground Floor	Nursery School	Educational
2.	First Floor	Cafeteria & Super Market	Assembly
3.	Second Floor	Banquet Hall	Assembly
4.	Third Floor	Gym	Assembly
5.	Fourth Floor	Recreation Room	Assembly

In view of the above details, Since the building is of Assembly Occupancy in 04 floors and is a Club House, Fire NOC is required for your building under reference.

This is for information

Yours faithfully

PRASANNA KUMAR B.J.E
District Fire Officer,
Public Information Officer
Fire Prevention Wing,
GHMC, Hyderabad.