



Cell: 9247173741

MOHAMMED ZAFARULLAH
M.A., LL.B.,
ADVOCATE

20-7-106, Qazipura, Hyderabad - 65.

GREATER HYDERABAD MUNICIPAL CORPORATION

Office of the Engineer-In-Chief,
Greater Hyderabad Municipal Corporation,
CC Complex, Tankbund Road,
Hyderabad.

U.O.Note No.ENC/GHMC/TA-I/K7/2007

Dated: -11-2007.

Sub: ENC - GHMC - Furnishing of structural design details of Reliance Towers on terrace of May flower Park apartments, Mallapur (Village) - Regarding.

Ref: 1. Note No.G2/884/2007, dated: 20-11-2007 Deputy Commissioner Kapra, G HMC.
2. Writ Petition No.23228 of 2007.

In the reference 1st cited above, a note file was submitted to this office for the technical report on the structural safety and stability of the apartment building. On verification of the information submitted, the following further details are required urgently for taking immediate necessary action.

- 1) Appendix of the Tor Steel (CIVIL -AID TECHNOCLINIC (P) LIMITED) Report.
- 2) STAAD input soft copy of the M/s Bright Info Tech.
- 3) Tower details
 - a) Detailed calculation of tower design.
 - b) Anchor bolt design and details for the worst load case.
 - c) Quality of concrete in the columns in which bolts are embedded.

The concerned Town Planning supervisor, who has brought the file to this office was already informed orally on 20-11-2007 and 21-11-2007 to furnish the above information immediately. As the issue is very urgent, I request to furnish the above information to this office immediately.


21/11/07
ENGINEER-IN-CHIEF

GHMC

21/11/07

To

The Deputy Commissioner,
Kapra Circle, Greater Hyderabad Municipal Corporation.

Copy to the Additional Commissioner(P&P), GHMC for information.

OFFICE OF THE DEPUTY COMMISSIONER, KAPRA CIRCLE, GHMC

No.G2/884/TPS-II/2007,

Date: 22-11-2007

INTIMATION

Sub:- **GHMC – KAPRA CIRCLE** – Town Planning – Furnishing of structural design details of Reliance Towers on terrace of May Flower Park Apartment, Mallapur village – Notice – Issued – Regarding.

Ref:- U.O. Note No.ENC/GHMC/TA-I/K7/2007, dated 21-11-2007 from Municipal Engineer-in-Chief, GHMC.

With reference to the subject cited, it is to inform that the Engineer-in-Chief, GHMC has requested this office to furnish the following information immediately shown below.

1. Appendix of the Tor Steel (CIVIL – AID TECHNOCLINIC (P) LIMITED) Report.
2. STAAD input soft copy of M/s Bright Info Tech.
3. Tower details.
 - a) Detailed calculation of tower design.
 - b) Anchor bolt design and details for the worst load case.
 - c) Quality of concrete in the columns in which bolts are embedded.

Therefore, M/s Modi Properties Investments (P) Limited and M/s Reliance Info com Limited are hereby directed to furnish the above information urgently within (24) hours from the date of receipt of this notice.

S. L. H. S.
**DEPUTY COMMISSIONER,
KAPRA CIRCLE, GHMC**

Encl: (1)

~~1.~~ To

[Signature]
M/s Modi Properties and Investments (P) Limited,
H.No.5-4-187/3&4, 2nd Floor,
M.G. Road,
SECUNDERABAD-500 003.
Fax No.040- 27544058.

2. M/s Reliance Info com Limited,
Lake Show Towers,
Raj Bhavan Road,
Somajiguda,
HYDERABAD.
Fax No.30331615.
Phone: 30331500.

Copy to the Engineer-in-Chief, GHMC for information.

Copy to the Municipal Engineer, Kapra Circle, GHMC for information.