

Office of
The Superintending Engineer
Operation RR Circle North,
Banrock, Secunderabad.

Sanction Memo No. SE/O/RRC(N) Coml. DR. No. 113/06/D. No. 351/06, date 17-05-06.

Electrification Operation, Ranga Reddy Circle (North) - extension of supply to 90 Nos. Single Phase each 2 KW, 30 Nos. 3 Phase each 3 KW domestic loads & 1 No. 20 KW common load to M/s. Summit Builders at Sy. No. 290, 290 (P), Cherlapally in Kushaiguda section of Sainikpuri sub division in Medchal division of RRC (N) in Ranga Reddy District - Estimate sanctioned - Regarding.

Ref: No. EEE OP-Medchal/AE Comml. D. No. 940/06, dated 12-05-06

The Superintending Engineers, Operation, Ranga Reddy Circle North administratively approves the proposal for extension of supply to 90 Nos. Single Phase each 2 KW, 30 Nos. 3 Phase each 3 KW domestic loads & 1 No. 20 KW common load to M/s. Summit Builders at Sy. No. 290, 290 (P), Cherlapally in Kushaiguda section of Sainikpuri sub division in Medchal division of RRC (N) in Ranga Reddy District and accords sanction for

Rs. 554,180 Rupees Five Lakh Fifty Four thousand One hundred Eighty Only

towards expenditure as per the detailed estimate enclosed.

The estimate is technically sanctioned and registered as D.R. No. 113 of 2006-2007.

CHARGEABLE TO CAPITAL :

Rs.			
A.	A.P.C.P.D.C.L.'s Side	Rs.	284,730
B.	Consumer's Side	Rs.	269,450
C.	TOTAL	Rs.	554,180

The classification of expenditure is given below:

A.P.C.P.D.C.L. - Capital out lay on electricity scheme - E. Arrears (B) Expenditure (3) Distribution System (Excluding S.S.) F. Distribution Plant (High Voltage) D. Distribution Plant (Medium and Low Voltage).

A.P.C.P.D.C.L. - Capital out lay on Electricity Scheme - E.H. Arrears B-12 suspense stock.

The sanction accorded now is subject to the following conditions.

1. Supply is liable to be staggered, restricted, reduced out of altogether, if so warranted by Power fuel shortage or water position or any other emergency.
2. Supply is liable to be disconnected, if used without permission of A.P.C.P.D.C.L. for purpose other than those for which it specifically sanctioned.
3. The proposed power to the premises should not have second service and no arrears pending and no court cases pending.
4. The proposed Distribution Transformer LT Lines should be in side of consumer premises only with necessary clearances and that equipment should not be in traffic movement area. **The proposed DTR and its equipments should be erected by maintaining proper horizontal clearances minimum of four feet distance from the building structure.**

Central Power Distribution Company of Andhra Pradesh Ltd.

5. In case of non - availability / non provision of space after due inspection and duly satisfying the contentions of the builder / developer the local Divisional Engineer / Operation may permit the developer / builder to provide space for erection of DTR in a closed room subject to providing of fire proof indoor dry type transformer by the builder with necessary cabling etc., at his cost. Access to such room should be provided by the builder ~~separately~~ to the staff of CPDCL.
6. There should not be any 11 KV/LT lines passing through from other source of supply in the proposed premises.
7. The LT Panel Boards are to be standardized with required protection and housing for meters with sealing arrangements.
8. The existing services if any in this premises to be provided in control panel only or that services to be dismantled and properly accounted for.
9. The Divisional Engineers (OP) are requested to followed the guide lines given in the Memo. No. CGM/ Comm/DE (CVAE - 1/F-Release of Services/D. No. 2883/03, dt : 28-11-03 before releasing the services sanctioned in this estimate.
10. The following amounts are to be collected from the consumer.
- a) **Rs. 269,450 Rupees Two Lakh Sixty Nine thousand Four hundred Fifty Only**
towards non-refundable service line charges.
- b) **Rs. 290000 Rupees Two Lakh Ninety thousand Only**
towards non-refundable load development charges.
- c) **Rs. 58000 Rupees Fifty Eight Thousand Only**
towards Security Deposit charges.


The work order approval will be issued by Divisional Engineers, Concerned subject to budget provision and in accordance with the policy laid down by the A.P.C.P.D.C.L, from time to time.

Work order should be issued only on receipt of a certificate along with W.O. application from the concerned Asst. Divisional Engineer to the effect that necessary payments has been collected.

Against the lump-sum provisions made in the estimate, detailed working estimate should be got approved by the competent authority.


The prospective consumer should give an under taking along with LT Power requisition, in the event of connecting up additional connected load in the premises, in excess of the contracted load.

Encl. : Estimate in the full shape.


Superintending Engineer
Operation Ranga Reddy Circle (North)

To
The Divisional Engineer/Operation/Medchal.
Copy to : The Accounts Officer, Expenditure, RR Circle North.
Copy to : The Asst. Divisional Engineers/Operation/Sainikpuri.
Copy to : The Asst. Engineer/Operation/Kushaiguda.
Copy submitted to the Chief General Manager/Comm/APCPDCL.
Copy submitted to the Chief General Manager/Operation/Ranga Reddy Zone.
NOTE : Ensure approval of CEIG for Electrical Installation of Multistoried Buildings having More than 15 Meters height under Rule 50 (a) I.E. Rules 1956.

FORWARDED BY ORDER


Asst. Divisional Engineer/Comm.
Gunrock, Sec underabad - 15.

To

Superintending Engineer
Operation RR Circle North,
Gunrock, Secunderabad - 15.

M/s. Summit Builders
Sy. No. 290, 290 (P),
Cherlapally, R. R. Dist..

LT. No. SE/O/RRC (N)/Coml./DR. No. 113/2006/D.No. 352/06, dt.17-05-06.

Sub :- Extension of supply to 90 Nos. Single Phase each 2 KW, 30 Nos. 3 Phase each 3 KW domestic loads & 1 No. 20 KW common load to M/s. Summit Builders at Sy. No. 290, 290 (P), Cherlapally in Kushaiguda section of Sainikpuri sub division in Medchal division of RRC (N) Estimate sanctioned - Permission for supply of materials and for execution of works by your self on turnkey basis - Accorded - Regarding.

Ref:- 1. Sanction Memo No. SE/O/RRCN/Comml./D. No. 351/06, Dt 17-05-06.
2. Representation of Consumer dated

Under the circumstances explained in reference (2) cited, you are permitted to supply the materials COMPLETELY & EXECUTE the works in respect of the scheme sanctioned under reference 2nd cited with the following details. :

- a) Erection of 315-KVA-Distribution-Transformer with AB Switch and HG Fuse set.
- b) Laying of 185 Sq. mm. 3 1/2 Core LT XLPE UG Cable DTR to LT Panle board for a distance of 50 Mts.
- c) Laying of 95 Sq. mm. 3 1/2 Core LT XLPE UG Cable LT Pánle board to LT Feeder Pillar Box for a distance of 60 Mts.
- d) LT Metering Pannel board with 400 A MCBs bus bar 400 A Alluminium bus bar and 25 Nos out going 32 A TPN MCBs.
- e) Erection of LT Distribution Pannel Board (Out door) with 600 A 3 Phase MCB's out going cable protection with bus bar of 600 A Capacity.
- f) Effecting of 90 Nos. Single Phase each 2 KW, 30 Nos. 3 Phase each 3 KW domestic loads, & 1 No. 20 KW common load

The permission now accorded is subject to the following conditions:

- 1 A licensed electrical contractor under the supervision of the APCPDCL's Officials, should execute the works.
- 2 The materials used in the works should confirm to APCPDCL's Specification.
- 3 Major materials like distribution transformers, A.B. Switches, H.G. Fuse sets, conductor, structural steel and other materials should be purchased from standard vendors of standard quality and as per latest ISI. The bills/ vouchers of materials purchased should be produced to Divisional Engineer, Operation, Medchal.
- 4 You should hand over all the works executed by you to the APCPDCL's Officials after completion in full shape. The work executed by you shall be taken over by the APCPDCL after statutory inspection of APCPDCL's officials. The installation shall be deemed to be the property of APCPDCL's after such take over. The proposed Distribution Transformer, LT Lines should be in side of consumer premises only.
- 5 The consumer should provide the LT Panel Boards are to be standardized with required protection and housing for meters with sealing arrangements.
- 6 The proposed power in the premises should not have 2nd service, arrears to be paid and no court case pending.

Central Power Distribution Company of Karnataka Limited

The proposed Distribution Transformer LT Lines should be in side of consumer premises only with necessary clearances and that equipment should not be in traffic movement area. The proposed DTR and its equipments should be erected by maintaining proper horizontal clearances minimum of four feet distance from the building structure.

- 8 In case of non-availability / non-provision of space after due inspection and duly satisfying the contentions of the builder / developer the local Divisional Engineer / Operation may permit the developer / builder to provide space for erection of DTR in a closed room subject to providing of fire proof indoor dry type transformer by the builder with necessary cabling etc., at his cost. Access to such room should be provided by the builder separately to the staff of CPDCL.
- 9 There should not be any 11.KV / LT Lines passing through from other source of supply in the proposed premises.
- 10 The existing services if any in this premises to be provided in the metering panel only or that services to be dismantled and properly accounted for.
- 11 Furnish approval of CEIG for your electrical installation if multistoried complex height is more than 15 Mts.
- 12 As the existing Power Transformer capacity and DTR Capacity and connected lines and equipment needs enhancement to cater the proposed loads. Hence development charges are being collected.
- 13 **315 KVA CSP Transformer** procured by you should be tested by Divisional Engineer /MRT/Ranga Reddy Circle (North).


i) To pay an amount of **Rs. 234420** **Rupees Two Lakh Thirty Four thousand Four hundred Twenty Only**

Towards 10% Supervision Charges on estimate cost, Balance Development Charges Transformer testing charges and Security Deposit by Demand Draft in favour of Divisional Engineer, Operation, Medchal and handed over to Divisional Engineer, Operation, Medchal.

DETAILS.			
i)	10% of Total estimate cost towards Supervision charges	Rs.	55418
ii)	Balance Development Charges (2,90,000-1,69,499)	Rs.	120501
iii)	315 KVA CSP Transformer testing charges	Rs.	500
iv)	Security Deposit at the rate of Rs. 200/- KW for domestic, Rs. 800/- KW for non domestic & Rs. 500/- HP.	Rs.	58000
Total AMOUNT TO BE PAID BY CONSUMER.		Rs.	234419
		Orsay	234420

You may contact Divisional Engineer, Operation, Medchal for further action in this matter.

Yours faithfully,


Superintending Engineer
Operation RR Circle North

- Copy to: The Divisional Engineer/Operation/Medchal.
- Copy to: The Accounts Officer, Expenditure, RR Circle North.
- Copy to: The Asst. Divisional Engineers/Operation/Sainikpuri.
- Copy to: The Asst. Engineer/Operation/Kushaiguda.
- Copy submitted to the Chief General Manager/Comm./APCPDCL.
- Copy submitted to the Chief General Manager/Operation/Ranga Reddy Zone.

They are requested to ensure that the works shall be carried out as per the standards set by CPDCL.

Central Power Distribution Company of Andhra Pradesh
STATEMENT FOR SERVICE LINE CHARGES AND DEVELOPMENT CHARGES

Extension of supply to 90 Nos. Single Phase each 2 KW, 30 Nos. 3 Phase each 3 KW domestic loads, 1 No. 20 KW common load to M/s. Summit Builders at Sy. No. 290, 290 (P), Cherlapally in Kushaiguda section of Sainikpuri sub division in Medchal division of RRC (N).

Sl. No.	Description	Units	Qty	Rate	Amount in Rs.
I	Total Cost of the Estimate				554180
b)	Less cost of 1 No. 315 KVA CSP DTR + SP Structure+ HG Fuse + AB Switch	Nos.	1	181329	181329
	Distribution Transformer				
c)	Less cost of				
	i) Energy Meters				
	Single Phase Meters	Nos.	90	602	54180
	Less cost of				
	ii) 3 Phase 10 - 40 A Energy Meters	Nos.	30	1404	42120
e)	Less Cost of CT Operated	Nos.	1	7100	7100
	LT Trivector Meter				
II	Total Expenditure chargeable to CPDCL				284729
				orsay	284730
III	Service line charges to be collected				269450
IV	Development charges to be collected	Services	Nos.	Load in KW	Dev. Charges
a)	Domestic @ Rs. 1000/- per KW	3 phase	90	2	180000
		3 phase	30	3	90000
		3 phase	1	20	20000
	Total amount in Rs.				290000
V	Security Deposit				
a)	Domestic @ Rs. 200/- per KW	3 phase	90	2	36000
		3 phase	30	3	18000
		3 phase	1	20	4000
	Total amount in Rs.				58000
VI	Total charges to be collected				617450

Superintending Engineer
 Operation Ranga Reddy Circle (North)


AGP

AG/C


Central Power Distribution Company of Andhra Pradesh Ltd.

REPORT TO ACCOMPANY THE ESTIMATE

- 1 General : The proposal is for extension of supply to 90 Nos. Single Phase each 2 KW, 30 Nos. 3 Phase each 3 KW domestic loads, & 1 No. 20 KW common load to M/s. Summit Builders at Sy. No. 290, 290 (P), Cherlapally in Kushaiguda section of Sainikpuri sub division in Medchal division of RRC (N).
- 2 Main Features : The Proposal envisages the following.
 - a) Erection of 315 KVA Distribution Transformer with AB Switch and HG Fuse set.
 - b) Laying of 185 Sq. mm. 3 1/2 Core LT XLPE UG Cable DTR to LT Panle board for a distance of 50 Mts.
 - c) Laying of 95 Sq. mm. 3 1/2 Core LT XLPE UG Cable LT Panle board to LT Feeder Pillar Box for a distance of 60 Mts.
 - d) LT Metering Pannel board with 400 A MCBs bus bar 400 A Alluminium bus bar and 25 Nos. out going 32 A TPN MCBs.
 - e) Erection of LT Distribution Pannel Board (Out door) with 600 A 3 Phase MCB's out going cable protection with bus bar of 600 A Capacity.
 - f) Effecting of 90 Nos. Single Phase each 2 KW, 30 Nos. 3 Phase each 3 KW domestic loads, & 1 No. 20 KW common load
- 3 33/11 KV Substation and Feeder : The proposed loads are on 11 KV Krup feeder emanating from 33/11 KV Sub - Station Cherlapally SS with existing Power Transformer Capacity 3 x 8 MVA is not capable of feeding proposed loads, already proposed loads and existing loads. Hence the development charges are being collected to enhance the PTR capacity and to strengthen the lines and equipments.
- 4 Capital Cost of the Estimate :- The total cost of the estimate is Rs.5,54,180 /- and it is self remunerative.
- 5 H.T. Regulation :- The H.T. Regulation of the feeder will be with in permissible limits as the proposed load is with in 2 to 3 KM vicinity of 33/11 KV Sub - Station.
- 6 List of Materials :- The required materials are as per the detailed estimate.


Superintending Engineer
Operation Ranga Reddy Circle (North)


A/11



A/11

Operation Ranga Reddy Circle (North)

DETAILED ESTIMATE FOR H.T. SYSTEM

Extension of supply to 90 Nos. Single Phase each 2 KW, 30 Nos. 3 Phase each 3 KW domestic loads, 1 No. 20 KW common load to M/s. Summit Builders at Sy. No. 290, 290 (P), Cheriapally in Kushaiguda section of Sainikpuri sub-division in Medchal division of RRC (N).

Sl. No.	Particulars	Qty.	Rate		Per	Amount	
			Material	Labour		Material	Labour
Distribution Transformer switch gear.							
	315 KVA CSP Distribution Transformer 11 KV/433 Volts.	1	No.	169499	2260	Each	169499 2260
	Single Pole structure with Box Pole of R.S. Joists welded Back to Back. (Including concreting and pit excavation etc.)	1	No.	14125	1500	Each	14125 1500
3	Plinth of standard size and fencing if necessary.	1	No.	5000	500	Each	5000 500
4	Fencing-around Transformer.	1	No.	5000	500	Each	5000 500
5	Earthing for Transformer (1No. Cast Iron and 2 Nos. GI Pipes)	1	No.	3000	500	Each	3000 500
6	11 KV H.G. Fuse set	1	No.	1230	255	Each	1230 255
7	11 KV AB Switch 200 Amps.	1	No.	4398	380	Each	4398 380
8	300 Sq. mm. 3 1/2 Core LT cable and distribution at Distribution Transformer Structure.	1	No.	7250	300	Each	7250 300
Sub Total Rs.							209502 6195
3% Contingencies							6285
3% S & H Charges							5985
Labour & Transport							6195
10% Estt. General Charges							22797
Grand Total : Rs.							250764
Or Say Rs.							250760


 Superintending Engineer
 Operation Ranga Reddy Circle (North)

Bill
8/6/11

✓
4/6/11

✓
4/6/11

Central Power Distribution Company
Operation Ranga Reddy Circle (North)

DETAILED ESTIMATE FOR L.T. SYSTEM

Extension of supply to 90 Nos. Single Phase each 2 KW, 30 Nos. 3 Phase each 3 KW domestic loads, 1 No. 20 KW common load to M/s. Summit Builders at Sy. No. 290, 290 (P), Cherlapally in Kushaiguda section of Sainikpuri sub division in Medchal division of RRC (N).

Sl. No.	Particulars	Qty.	Rate		Per	Amount	
			Material	Labour		Material	Labour
1	Distribution Cables						
a)	P.V.C. Cable 185 Sq. mm. 3 1/2 Core XLPE UG Cable	50 Mts.	291	120	Mts.	14550	6000
a)	P.V.C. Cable 95 Sq. mm. 3 1/2 Core XLPE UG Cable	60 Mts.	178	100	Mts.	10680	6000
2	L.T. Switch gear Installation						
a)	LT Distribution Pannel Board (Out door) with 600 A 3 Phase MCB's outgoing cable protection with bus bar of 600 A Capacity.	2 Nos.	30000	3000	Each	60000	6000
b)	LT Metering Pannel Board with 400 A MCCB's with 400 A Alluminium bus bar and 25 Nos. outgoing 32 A TPN MCB's.	6 Nos.	8000	300	Each	48000	4800
c)	Jointing Material	LS Nos.	500		LS	500	
3 a)	3 Phase 10 - 40 A Energy Meter (high quality)	30 Nos.	1404	50	Each	42120	1500
b)	Single Phase 5-20 A Energy Meters (high quality)	90 Nos.	602	30	Each	54180	2700
c)	CT operated LT Trivector Meter	1 Nos.	7100	580	Each	7100	580
Sub Total Rs.						237130	27580
3% Contingencies						7114	
3% S & H Charges						4012	
Labour & Transport						27580	
10% Estt. General Charges						27584	
Grand Total : Rs.						303419	
Or Say Rs.						303420	

ABSTRACT

Total of H.T.	Rs.	250760
Total of L.T.	Rs.	303420
Total Cost of Estimate Total	Rs.	554180

Superintending Engineer
Operation Ranga Reddy Circle (North)

Dr
26/11

ADP

ADP

22096

Central Power Distribution Company of A.P. Limited
OPERATION CIRCLE, RANGA REDDY (NORTH)

a) Sanction No.
b) W.O. No.
c) Board's portion estimated charges

K-190
TEST REPORT
PART - A

S.C. No.	2209-3375
Distribution	Cherlapally
Date	18/11/08

(To be filled in by Distribution Engineers)

- 1) a) Name of the Consumer :
(Full Surname and Name in block letters)
- b) Father's Name in block letters
- c) In case the consumer is not owner of the premises specify owners name and address
- 2) Premises to which supply relates specify
 - i) Nature of Business :
 - ii) Purpose in case of non domestic / Industrial supply :
 - iii) Type of Industry :
(Specify small scale or Cottage)
- 3) Particulars of premises to which supply relates Door No.
S.F. No.
Street
Town / Village
- 4) Permanent address of Consumer : Door No.
Street
Town / Village

M/S. Summit
Builders
Pyno. 290 & 280ft
Cherlapally

- 5) Other S.C No. / Distribution in the name of the above consumer under the A.P. Electricity Board (Full details to be furnished.)
 - a) Whether the service now released is for a new premises or to a old premises to a new consumer (Specify the S.C. No. if any available, already under disconnection)
 - b) Whether a clearance certificate is obtained from the Electricity Revenue Office before releasing the supply to new consumer in the old premises :

6) Particulars of connected load.	No. of Points	Wattage Points	Total Wattage
i) LIGHTING :			
Lights			3 pu
Fans			
Convenient wall plugs for Light and Fans			
ii) DOMESTIC / NON DOMESTIC ELECTRICAL APPARATUS :			
Cookers			
Water Heaters			
Pumpsets			
Motors			
Other purposes (Specify Details)			
Convenient wall plugs 5 Amps / 15.Amps.			
iii) STREET LIGHT :			
No. of Fixtures			
Installed by Board / Consumer			
Connected Load			
iv) INDUSTRIAL :			
Rice Ruling			
Oil Pressing			
Ginning			
Other purposes (Specify nature of Industry)			
MOTORS			
(Furnish name plate details make etc. of the motor installed)			
v) AGRICULTURAL			
Other purposes (Specify details)			
	Pumpsets		
	Total		3 pu

P.T.O.

- 7) i) Insulation between conductor and earth
 ii) Insulation between Phase :

Polyphase / single phase

- 8) Nature of Supply
 9) Particulars of Meter
 Whether owned by consumer/Bard
 10) Particulars of Seals fixed to the Meter :

Meter No.	Capacity & Type	Multiplying Factor	Initial Reading	Meter Make
12345	20	5	1234	AL

Location	No. of Seals	Impression on seals	Type of Sealer	Sl. No. of Seals
a) Meter Cover				
b) Terminal Cover				
c) Meter Box				
d) Cut-out	2			

- 11) Tariff Applicable
 12) Security Deposit : 2,34,420/-
 13) Agreement position :
 (Despatch No. Agreement Regd. Item No. etc.)
 14) a) Connected load
 b) Connected load (as per sanctioned estimate)
 15) Tariff guarantee :
 a) Special Guarantee : 49
 16) Date of commencement of supply :
 17) a) Date of expiry of three months notice (for power services)
 b) Whether the U.C.M. Charges were paid before releasing the services (furnish P.C.B. No. and date D.D. No. etc. / Receipt No. of the E.R.O. where payment is made at E.R.O.)

Monthly Minimum / Annual Minimum
 D.D. No. 124115 PCB No.
 & Date 17.6.06 & Date

(in words)
 (in words)

Rs. Rs. per H.P.

- 18) Whether the land or the premises relates to the owner (consent letter of the owner of indemnity bond to be enclosed)
 I am a witness to the above particulars and seals were put in my presence

- 1) WITNESS :
 2) WITNESS :
 LINE INSPECTOR
 Forwarded to A.A.O. / ERO. _____

SIGNATURE OF THE CONSUMER

ADDL. ASST. ENGINEER / Asst. Divl. Engineer
 DISTRIBUTION : WITH DATE
 ADDL. ASST. ENGINEER
 ASSISTANT DIVL. ENGINEER

PART 'B'

- | | |
|----------------------------------|---------------------------------------|
| 1) Security Deposit Register : | Item No.
Folio No.
S D Vol. No. |
| 2) Service Connection Register : | Item No.
Folio No.
Vol. No. |
| 3) Agreement Register : | Item No.
Folio No.
Vol. No. |
| 4) A.M.G. Calender : | Item No.
Folio No. |
| 5) Consumer Ledger : | Item No.
S.C.No. |

Ledger Folio Opened to entries completed Meter Card Opened

Billing Superintendent :

Jr. Accounts Officer

Asst. Accounts Officer
 Electricity Revenue Office

- Note.. a) No. column should be left unfilled.
 b) S.F. No. Should invariably recorded for all the agricultural services to link up the services with the agreement.

Central Power Distribution Company of A.P. Limited
OPERATION CIRCLE, RANGA REDDY (NORTH)

a) Sanction No.
 b) W.O. No.
 c) Board's portion estimated charges

TEST REPORT
PART - A

S.C. No. 2209-2296
 Distribution Cherlapally
 Date 18/11/06

(To be filled in by Distribution Engineers)

- 1) a) Name of the Consumer :
 (Full Surname and Name in block letters)
 b) Father's Name in block letters
 c) In case the consumer is not owner of the premises specify owners name and address
- 2) Premises to which supply relates specify
 i) Nature of Business :
 ii) Purpose in case of non domestic / Industrial supply :
 iii) Type of industry :
 (Specify small scale or Cottage)
- 3) Particulars of premises to which supply relates Door No.
 S.F. No.
 Street
 Town / Village

M/S. Summit Builders
By No. 290 & 290/10
Cherlapally

- 4) Permanent address of Consumer : Door No.
 Street
 Town / Village
- 5) Other S.C. No. / Distribution in the name of the above consumer under the A.P. Electricity Board (Full details to be furnished.)
 a) Whether the service now released is for a new premises or to a old premises to a new consumer (Specify the S.C. No. if any available, already under disconnection)
 b) Whether a clearance certificate is obtained from the Electricity Revenue Office before releasing the supply to new consumer in the old premises :

- 6) Particulars of connected load.
 i) LIGHTING :

Lights
 Fans
 Convenient wall plugs for Light and Fans

ii) DOMESTIC / NON DOMESTIC ELECTRICAL APPARATUS :
 Cookers
 Water Heaters
 Pumpsets
 Motors
 Other purposes (Specify Details) .
 Convenient wall plugs 5 Amps / 15 Amps.

- iii) STREET LIGHT :
 No. of Fixtures
 Ordinary Filament Lamps
 M.V. Lamps
 Flourescent Lamps
 Blended Lamps

- Installed by Board / Consumer
 Connected Load
- iv) INDUSTRIAL :
 Rice Fuling
 Oil Pressing
 Ginning
 Other purposes (Specify nature of Industry)

- MOTORS
 (Furnish name plate details make etc. of the motor installed)

- v) AGRICULTURAL
 Other purposes (Specify details) .

No. of Points	Waltage Points	Total Waltage
		<i>3 pu</i>

Pumpsets : _____
 Total *3 pu*

P.T.O.

- 7) i) Insulation between conductor and earth
 ii) Insulation between Phase

Meter No.	Capacity & Type	Multiplying Factor	Initial Reading	Meter Make
130929		3	520A	

- 8) Nature of Supply
 9) Particulars of Meter Whether owned by consumer/Bard
 10) Particulars of Seals fixed to the Meter :

Location	No. of Seals	Impression on seals	Type of Sealer	Sl. No. of Seals
a) Meter Cover				
b) Terminal Cover				
c) Meter Box				
d) Cut-out				

- 11) Tariff Applicable
 12) Security Deposit : 224, 420/-
 13) Agreement position : (Despatch No. Agreement Regd. Item No. etc.)
 14) a) Connected load (in words)
 b) Connected load (as per sanctioned estimate) (in words)
 15) Tariff guarantee :
 a) Special Guarantee :
 16) Date of commencement of supply :
 17) a) Date of expiry of three months notice (for power services)
 b) Whether the U.C.M. Charges were paid before releasing the services (furnish P.C.B. No. and date D.D. No. etc. / Receipt No. of the E.R.O. where payment is made at E.R.O.)
 18) Whether the land or the premises relates to the owner (consent letter of the owner of indemnity bond to be enclosed)

Monthly Minimum / Annual Minimum
 D.D. No. 124118 PCB No.
 & Date & Date
 Rs. 776.06 per H.P.

I am a witness to the above particulars and seals were put in my presence
 1) WITNESS :
 2) WITNESS :
 LINE INSPECTOR
 Forwarded to A.A.O. / ERO.

[Signature]
 SIGNATURE OF THE CONSUMER
 Addl. Asst. Engineer / Asst. Divl. Engineer
 DISTRIBUTION : WITH DATE
 ADDL. ASST. ENGINEER
 ASSISTANT DIVL. ENGINEER

PART 'B'

- 1) Security Deposit Register : Item No. Folio No. S D Vol. No.
 2) Service Connection Register : Item No. Folio No. Vol. No.
 3) Agreement Register : Item No. Folio No. Vol. No.
 4) A.M.G. Calender : Item No. Folio No.
 5) Consumer Ledger : Item No. S.C.No.

Ledger Folio Opened to entries completed Meter Card Opened

Billing Superintendent : **Jr. Accounts Officer** Asst. Accounts Officer
 Electricity Revenue Office

Note. a) No. column should be left unfilled.
 b) S.F. No. Should invariably recorded for all the agricultural services to link up the services with the agreement.