

QC - Concrete Cube Testing Report.															
Company:		MMR(LLP)													
Project:		GHT													
Report for Month:		Feb - Mar = 2022.													
Prepared By:		QC Team													
Date:		28-03-2022													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of these tests	Remarks
18201	02-02-2022	Site Mix	M25	Homeline	A-601,602,616		col	8	3-3-22	29	25.0	595.0	26.4		
											25.0	555.0	24.7	25.4	
											25.0	565.0	25.1		
18202	09-02-2022	Rmc	M20	Homeline	A-503-505,514		slab	7	10-3-22	29	20.0	455.0	20.2		
											20.0	470.0	20.9	20.3	
											20.0	445.0	19.8		
18203	15-02-2022	Site Mix	M25	Homeline	A-603-605,614		col	8	23-2-22	8	17.5	395.0	17.6		
											17.5	390.0	17.3	17.5	
											17.5	395.0	17.6		
18203	15-02-2022	Site Mix	M25	Homeline	A-603-605,614		col	8	16-3-22	29	25.0	595.0	26.4		
											25.0	560.0	24.9	25.5	
											25.0	565.0	25.1		
18204	01-03-2022	Rmc	M20	Homeline	A-601,602,610		slab	8	10-3-22	9	14.0	335.0	14.9		
											14.0	335.0	14.9	14.7	
											14.0	320.0	14.2		
18204	01-03-2022	Rmc	M20	Homeline	A-601,602,610		slab	8	30-3-22	29	20.0	435.0	19.3		
											20.0	455.0	20.2	20.1	
											20.0	465.0	20.7		