QC - Concrete Cube Testing Report.

Company: MRGV

Project: BRGV

Report for Month: Mar - April = 2022..

Prepared By: QC Team

Date: 03-05-2022

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
21024	16-03-2022	RMC	M25	Homeline		A	Footings		15-4-22	30	25.0	565.0	25.1		
											25.0	565.0	25.1	25.5	
											25.0	590.0	26.2		