

QC - Concrete Cube Testing Report.															
Company:		SOVLLP													
Project:		SOV													
Report for Month:		Mar - April = 2022.													
Prepared By:		QC Team													
Date:		27-04-2022													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
7790	06-03-2022	Rmc	M20	SCPL		153	Slab	2	4-4-22	29	20.0	460.0	20.4		
											20.0	450.0	20.0	20.1	
											20.0	450.0	20.0		
7791	06-03-2022	Rmc	M20	SCPL		156	Slab	3	4-4-22	29	20.0	465.0	20.7		
											20.0	455.0	20.2	20.4	
											20.0	455.0	20.2		
7792	06-03-2022	Rmc	M20	SCPL		157	Slab	2	4-4-22	29	20.0	470.0	20.9		
											20.0	460.0	20.4	20.6	
											20.0	460.0	20.4		
7793	06-03-2022	Rmc	M20	SCPL		149	Slab	1	4-4-22	29	20.0	475.0	21.1		
											20.0	460.0	20.4	20.6	
											20.0	455.0	20.2		
7794	06-03-2022	Rmc	M20	SCPL		150	Slab	1	4-4-22	29	20.0	465.0	20.7		
											20.0	455.0	20.2	20.3	
											20.0	450.0	20.0		
7795	08-03-2022	Rmc	M20	SCPL		171	footings		4-4-22	27	20.0	475.0	21.1		
											20.0	455.0	20.2	20.1	
											20.0	425.0	18.9		
7796	16-03-2022	Rmc	M25	mhpl		commercial	columns	5	14-4-22	29	25.0	580.0	25.8		
											25.0	580.0	25.8	25.9	
											25.0	585.0	26.0		
7797	17-03-2022	Rmc	M20	Ishaq		177	Slab	1	14-4-22	28	20.0	460.0	20.4		
											20.0	470.0	20.9	20.8	
											20.0	475.0	21.1		
7798	17-03-2022	Rmc	M20	Ishaq		178	Slab	1	14-4-22	28	20.0	465.0	20.7		
											20.0	475.0	21.1	20.9	
											20.0	470.0	20.9		
7799	17-03-2022	Rmc	M20	Ishaq		173	footings		14-4-22	28	20.0	455.0	20.2		
											20.0	465.0	20.7	20.2	
											20.0	445.0	19.8		
7800	17-03-2022	Rmc	M20	Ishaq		188	footings		14-4-22	28	20.0	455.0	20.2		
											20.0	470.0	20.9	20.1	
											20.0	435.0	19.3		
7801	17-03-2022	Rmc	M20	SCPL		159	Slab	2	14-4-22	28	20.0	495.0	22.0		
											20.0	480.0	21.3	21.6	
											20.0	480.0	21.3		
7802	19-03-2022	Rmc	M25	Vasanthi		148	columns	2	27-3-22	8	17.5	395.0	17.6		
											17.5	395.0	17.6	17.7	
											17.5	405.0	18.0		

7802	19-03-2022	Rmc	M25	Vasanthi		148	columns	2	17-4-22	29	25.0	595.0	26.4		
											25.0	575.0	25.6	25.7	
											25.0	565.0	25.1		
7803	19-03-2022	Rmc	M25	Vasanthi		149	columns	2	27-3-22	8	17.5	400.0	17.8		
											17.5	395.0	17.6	17.8	
											17.5	405.0	18.0		
7803	19-03-2022	Rmc	M25	Vasanthi		149	columns	2	17-4-22	29	25.0	600.0	26.7		
											25.0	580.0	25.8	25.9	
											25.0	570.0	25.3		
7804	26-03-2022	Rmc	M20	Vasanthi		147	footings		3-4-22	8	14.0	335.0	14.9		
											14.0	345.0	15.3	14.8	
											14.0	320.0	14.2		
7804	26-03-2022	Rmc	M20	Vasanthi		147	footings		24-4-22	29	20.0	455.0	20.2		
											20.0	455.0	20.2	20.4	
											20.0	465.0	20.7		
7805	26-03-2022	Rmc	M25	Vasanthi		150	columns	2	3-4-22	8	17.5	410.0	18.2		
											17.5	385.0	17.1	17.4	
											17.5	380.0	16.9		
7805	26-03-2022	Rmc	M25	Vasanthi		150	columns	2	24-4-22	29	25.0	595.0	26.4		
											25.0	580.0	25.8	25.8	
											25.0	565.0	25.1		
7806	05-04-2022	Rmc	M20	Ishaq		175	plinth		13-4-22	8	14.0	340.0	15.1		
											14.0	320.0	14.2	14.6	
											14.0	325.0	14.4		
7807	05-04-2022	Rmc	M20	Vasanthi		151	plinth		13-4-22	8	14.0	345.0	15.3		
											14.0	325.0	14.4	14.5	
											14.0	310.0	13.8		
7808	06-04-2022	Rmc	M20	mhlpl		commercial	Slab	5	13-4-22	7	14.0	350.0	15.6		
											14.0	320.0	14.2	14.6	
											14.0	315.0	14.0		