

QC - Concrete Cube Testing Report.																	
Company:		MMR(LLP)															
Project:		GHT															
Report for Month:		Mar - April = 2022.															
Prepared By:		QC Team															
Date:		27-04-2022															
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests			Remarks
18205	05-03-2022	Rmc	M25	Homeline	A-701,702,710		col	9	13-3-22	8	17.5 17.5 17.5	395.0 405.0 395.0	17.6 18.0 17.6	17.7			
18205	05-03-2022	Rmc	M25	Homeline	A-701,702,710		col	9	3-4-22	29	25.0 25.0 25.0	595.0 560.0 565.0	26.4 24.9 25.1	25.5			
18206	12-03-2022	Rmc	M20	Homeline	A-603-605,614		slab	8	20-3-22	8	14.0 14.0 14.0	335.0 335.0 320.0	14.9 14.9 14.2	14.7			
18206	12-03-2022	Rmc	M20	Homeline	A-603-605,614		slab	8	10-4-22	29	20.0 20.0 20.0	435.0 455.0 465.0	19.3 20.2 20.7	20.1			
18207	16-03-2022	Site Mix	M25	Homeline	A-703-705,714		col	9	24-3-22	8	17.5 17.5 17.5	410.0 390.0 395.0	18.2 17.3 17.6	17.7			
18207	16-03-2022	Site Mix	M25	Homeline	A-703-705,714		col	9	14-4-22	29	25.0 25.0 25.0	590.0 565.0 585.0	26.2 25.1 26.0	25.8			