QC - Concrete Cube Testing Report.

Company: GVDC

Project: Genopolis

Report for Month: April - May = 2022.

Prepared By: QC Team

Date: 06-06-2022

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
20164	09-04-2022	RMC	M35	Surasani		191	COL	3	18-4-22	9	23.5	530.0	23.6		
											23.5	540.0	24.0	23.9	
											23.5	545.0	24.2		
20164	09-04-2022	RMC	M35	Surasani		191	COL	3	9-5-22	30	35.0	795.0	35.3		
											35.0	815.0	36.2	35.6	
											35.0	795.0	35.3		