

QC - Concrete Cube Testing Report.															
Company:		SOVLLP													
Project:		SOV													
Report for Month:		May - June = 2022.													
Prepared By:		QC Team													
Date:		06-07-2022													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
7814	02-05-2022	Site Mix	M25	SCPL		153	col	3	31-5-22	29	25.0	585.0	26.0		
											25.0	595.0	26.4	26.3	
											25.0	595.0	26.4		
7815	02-05-2022	Site Mix	M25	SCPL		154	col	3	31-5-22	29	25.0	580.0	25.8		
											25.0	590.0	26.2	26.1	
											25.0	590.0	26.2		
7816	04-05-2022	Rmc	M25	SCPL		155	col	3	31-5-22	27	25.0	575.0	25.6		
											25.0	585.0	26.0	25.9	
											25.0	585.0	26.0		
7817	04-05-2022	Rmc	M20	Ishaq		174	plinth		31-5-22	27	20.0	475.0	21.1		
											20.0	465.0	20.7	20.7	
											20.0	455.0	20.2		
7818	05-05-2022	Rmc	M20	Vasanthi		148	Slab	2	3-6-22	29	20.0	470.0	20.9		
											20.0	460.0	20.4	20.4	
											20.0	450.0	20.0		
7819	05-05-2022	Rmc	M20	Vasanthi		149	Slab	2	3-6-22	29	20.0	465.0	20.7		
											20.0	455.0	20.2	20.2	
											20.0	445.0	19.8		
7820	05-05-2022	Rmc	M20	Vasanthi		150	Slab	2	3-6-22	29	20.0	460.0	20.4		
											20.0	460.0	20.4	20.3	
											20.0	450.0	20.0		
7821	05-05-2022	Rmc	M25	Ishaq		175	col	1	3-6-22	29	25.0	570.0	25.3		
											25.0	580.0	25.8	25.6	
											25.0	580.0	25.8		
7822	11-05-2022	Rmc	M20	Ishaq		172	plinth		8-6-22	28	20.0	455.0	20.2		
											20.0	455.0	20.2	20.2	
											20.0	455.0	20.2		
7823	11-05-2022	Rmc	M25	Ishaq		170	col	1	8-6-22	28	25.0	565.0	25.1		
											25.0	575.0	25.6	25.4	
											25.0	575.0	25.6		
7824	15-05-2022	Site Mix	M25	Vasanthi		148	col	3	13-6-22	29	25.0	560.0	24.9		
											25.0	570.0	25.3	25.2	
											25.0	570.0	25.3		
7825	15-05-2022	Site Mix	M25	Vasanthi		149	col	3	13-6-22	29	25.0	595.0	26.4		
											25.0	595.0	26.4	26.4	
											25.0	590.0	26.2		
7826	16-05-2022	Rmc	M20	Ishaq		171	plinth		13-6-22	28	20.0	460.0	20.4		
											20.0	460.0	20.4	20.3	
											20.0	450.0	20.0		
7827	16-05-2022	Rmc	M25	Ishaq		179	col	2	13-6-22	28	25.0	590.0	26.2		
											25.0	590.0	26.2	26.1	
											25.0	585.0	26.0		

7828	17-05-2022	Rmc	M25	Ishaq		178	col	2	14-6-22	28	25.0	585.0	26.0		
											25.0	585.0	26.0	25.8	
											25.0	570.0	25.3		
7829	18-05-2022	Rmc	M20	Ishaq		168	Slab	1	26-5-22	8	14.0	325.0	14.4		
											14.0	320.0	14.2	14.3	
											14.0	320.0	14.2		
7829	18-05-2022	Rmc	M20	Ishaq		168	Slab	1	16-6-22	29	20.0	465.0	20.7		
											20.0	465.0	20.7	20.6	
											20.0	460.0	20.4		
7830	18-05-2022	Rmc	M20	Ishaq		176	Slab	1	26-5-22	8	14.0	330.0	14.7		
											14.0	325.0	14.4	14.5	
											14.0	325.0	14.4		
7830	18-05-2022	Rmc	M20	Ishaq		176	Slab	1	16-6-22	29	20.0	465.0	20.7		
											20.0	460.0	20.4	20.4	
											20.0	455.0	20.2		
7831	20-05-2022	Rmc	M20	Scpl		158	Slab	2	26-5-22	6	14.0	340.0	15.1		
											14.0	325.0	14.4	14.7	
											14.0	325.0	14.4		
7831	20-05-2022	Rmc	M20	Scpl		158	Slab	2	18-6-22	29	20.0	470.0	20.9		
											20.0	460.0	20.4	20.4	
											20.0	450.0	20.0		
7832	20-05-2022	Rmc	M20	Scpl		155	Slab	3	26-5-22	6	14.0	345.0	15.3		
											14.0	330.0	14.7	14.8	
											14.0	325.0	14.4		
7832	20-05-2022	Rmc	M20	Scpl		155	Slab	3	18-6-22	29	20.0	475.0	21.1		
											20.0	465.0	20.7	20.7	
											20.0	455.0	20.2		
7833	20-05-2022	Rmc	M20	Scpl		154	Slab	3	26-5-22	6	14.0	340.0	15.1		
											14.0	325.0	14.4	14.5	
											14.0	315.0	14.0		
7833	20-05-2022	Rmc	M20	Scpl		154	Slab	3	18-6-22	29	20.0	470.0	20.9		
											20.0	455.0	20.2	20.3	
											20.0	445.0	19.8		
7834	20-05-2022	Rmc	M20	Scpl		153	Slab	3	26-5-22	6	14.0	345.0	15.3		
											14.0	335.0	14.9	14.8	
											14.0	320.0	14.2		
7834	20-05-2022	Rmc	M20	Scpl		153	Slab	3	18-6-22	29	20.0	475.0	21.1		
											20.0	450.0	20.0	20.6	
											20.0	465.0	20.7		
7835	22-05-2022	Rmc	M20	Ishaq		173	plinth		30-5-22	8	14.0	355.0	15.8		
											14.0	330.0	14.7	14.7	
											14.0	310.0	13.8		
7835	22-05-2022	Rmc	M20	Ishaq		173	plinth		20-6-22	29	20.0	480.0	21.3		
											20.0	455.0	20.2	20.7	
											20.0	460.0	20.4		
7836	22-05-2022	Rmc	M25	Ishaq		177	col	2	30-5-22	8	17.5	395.0	17.6		
											17.5	395.0	17.6	17.8	
											17.5	410.0	18.2		
7836	22-05-2022	Rmc	M25	Ishaq		177	col	2	20-6-22	29	25.0	595.0	26.4		
											25.0	595.0	26.4	26.3	
											25.0	585.0	26.0		
7837	24-05-2022	Rmc	M20	Ishaq		166	Slab	1	1-6-22	8	14.0	355.0	15.8		

[illegible]

QC - Concrete Cube Testing Report.															
Company:		SOVLLP													
Project:		SOV													
Report for Month:		May - June = 2022.													
Prepared By:		QC Team													
Date:		06-07-2022													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
7814	02-05-2022	Site Mix	M25	SCPL		153	col	3	31-5-22	29	25.0	585.0	26.0		
											25.0	595.0	26.4	26.3	
											25.0	595.0	26.4		
7815	02-05-2022	Site Mix	M25	SCPL		154	col	3	31-5-22	29	25.0	580.0	25.8		
											25.0	590.0	26.2	26.1	
											25.0	590.0	26.2		
7816	04-05-2022	Rmc	M25	SCPL		155	col	3	31-5-22	27	25.0	575.0	25.6		
											25.0	585.0	26.0	25.9	
											25.0	585.0	26.0		
7817	04-05-2022	Rmc	M20	Ishaq		174	plinth		31-5-22	27	20.0	475.0	21.1		
											20.0	465.0	20.7	20.7	
											20.0	455.0	20.2		
7818	05-05-2022	Rmc	M20	Vasanthi		148	Slab	2	3-6-22	29	20.0	470.0	20.9		
											20.0	460.0	20.4	20.4	
											20.0	450.0	20.0		
7819	05-05-2022	Rmc	M20	Vasanthi		149	Slab	2	3-6-22	29	20.0	465.0	20.7		
											20.0	455.0	20.2	20.2	
											20.0	445.0	19.8		
7820	05-05-2022	Rmc	M20	Vasanthi		150	Slab	2	3-6-22	29	20.0	460.0	20.4		
											20.0	460.0	20.4	20.3	
											20.0	450.0	20.0		
7821	05-05-2022	Rmc	M25	Ishaq		175	col	1	3-6-22	29	25.0	570.0	25.3		
											25.0	580.0	25.8	25.6	
											25.0	580.0	25.8		
7822	11-05-2022	Rmc	M20	Ishaq		172	plinth		8-6-22	28	20.0	455.0	20.2		
											20.0	455.0	20.2	20.2	
											20.0	455.0	20.2		
7823	11-05-2022	Rmc	M25	Ishaq		170	col	1	8-6-22	28	25.0	565.0	25.1		
											25.0	575.0	25.6	25.4	
											25.0	575.0	25.6		
7824	15-05-2022	Site Mix	M25	Vasanthi		148	col	3	13-6-22	29	25.0	560.0	24.9		
											25.0	570.0	25.3	25.2	
											25.0	570.0	25.3		
7825	15-05-2022	Site Mix	M25	Vasanthi		149	col	3	13-6-22	29	25.0	595.0	26.4		
											25.0	595.0	26.4	26.4	
											25.0	590.0	26.2		
7826	16-05-2022	Rmc	M20	Ishaq		171	plinth		13-6-22	28	20.0	460.0	20.4		
											20.0	460.0	20.4	20.3	
											20.0	450.0	20.0		
7827	16-05-2022	Rmc	M25	Ishaq		179	col	2	13-6-22	28	25.0	590.0	26.2		
											25.0	590.0	26.2	26.1	
											25.0	585.0	26.0		

7828	17-05-2022	Rmc	M25	Ishaq		178	col	2	14-6-22	28	25.0	585.0	26.0		
											25.0	585.0	26.0	25.8	
											25.0	570.0	25.3		
7829	18-05-2022	Rmc	M20	Ishaq		168	Slab	1	26-5-22	8	14.0	325.0	14.4		
											14.0	320.0	14.2	14.3	
											14.0	320.0	14.2		
7829	18-05-2022	Rmc	M20	Ishaq		168	Slab	1	16-6-22	29	20.0	465.0	20.7		
											20.0	465.0	20.7	20.6	
											20.0	460.0	20.4		
7830	18-05-2022	Rmc	M20	Ishaq		176	Slab	1	26-5-22	8	14.0	330.0	14.7		
											14.0	325.0	14.4	14.5	
											14.0	325.0	14.4		
7830	18-05-2022	Rmc	M20	Ishaq		176	Slab	1	16-6-22	29	20.0	465.0	20.7		
											20.0	460.0	20.4	20.4	
											20.0	455.0	20.2		
7831	20-05-2022	Rmc	M20	Scpl		158	Slab	2	26-5-22	6	14.0	340.0	15.1		
											14.0	325.0	14.4	14.7	
											14.0	325.0	14.4		
7831	20-05-2022	Rmc	M20	Scpl		158	Slab	2	18-6-22	29	20.0	470.0	20.9		
											20.0	460.0	20.4	20.4	
											20.0	450.0	20.0		
7832	20-05-2022	Rmc	M20	Scpl		155	Slab	3	26-5-22	6	14.0	345.0	15.3		
											14.0	330.0	14.7	14.8	
											14.0	325.0	14.4		
7832	20-05-2022	Rmc	M20	Scpl		155	Slab	3	18-6-22	29	20.0	475.0	21.1		
											20.0	465.0	20.7	20.7	
											20.0	455.0	20.2		
7833	20-05-2022	Rmc	M20	Scpl		154	Slab	3	26-5-22	6	14.0	340.0	15.1		
											14.0	325.0	14.4	14.5	
											14.0	315.0	14.0		
7833	20-05-2022	Rmc	M20	Scpl		154	Slab	3	18-6-22	29	20.0	470.0	20.9		
											20.0	455.0	20.2	20.3	
											20.0	445.0	19.8		
7834	20-05-2022	Rmc	M20	Scpl		153	Slab	3	26-5-22	6	14.0	345.0	15.3		
											14.0	335.0	14.9	14.8	
											14.0	320.0	14.2		
7834	20-05-2022	Rmc	M20	Scpl		153	Slab	3	18-6-22	29	20.0	475.0	21.1		
											20.0	450.0	20.0	20.6	
											20.0	465.0	20.7		
7835	22-05-2022	Rmc	M20	Ishaq		173	plinth		30-5-22	8	14.0	355.0	15.8		
											14.0	330.0	14.7	14.7	
											14.0	310.0	13.8		
7835	22-05-2022	Rmc	M20	Ishaq		173	plinth		20-6-22	29	20.0	480.0	21.3		
											20.0	455.0	20.2	20.7	
											20.0	460.0	20.4		
7836	22-05-2022	Rmc	M25	Ishaq		177	col	2	30-5-22	8	17.5	395.0	17.6		
											17.5	395.0	17.6	17.8	
											17.5	410.0	18.2		
7836	22-05-2022	Rmc	M25	Ishaq		177	col	2	20-6-22	29	25.0	595.0	26.4		
											25.0	595.0	26.4	26.3	
											25.0	585.0	26.0		
7837	24-05-2022	Rmc	M20	Ishaq		166	Slab	1	1-6-22	8	14.0	355.0	15.8		

[illegible]

QC - Concrete Cube Testing Report.															
Company:		SOVLLP													
Project:		SOV													
Report for Month:		May - June = 2022.													
Prepared By:		QC Team													
Date:		06-07-2022													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
7814	02-05-2022	Site Mix	M25	SCPL		153	col	3	31-5-22	29	25.0	585.0	26.0		
											25.0	595.0	26.4	26.3	
											25.0	595.0	26.4		
7815	02-05-2022	Site Mix	M25	SCPL		154	col	3	31-5-22	29	25.0	580.0	25.8		
											25.0	590.0	26.2	26.1	
											25.0	590.0	26.2		
7816	04-05-2022	Rmc	M25	SCPL		155	col	3	31-5-22	27	25.0	575.0	25.6		
											25.0	585.0	26.0	25.9	
											25.0	585.0	26.0		
7817	04-05-2022	Rmc	M20	Ishaq		174	plinth		31-5-22	27	20.0	475.0	21.1		
											20.0	465.0	20.7	20.7	
											20.0	455.0	20.2		
7818	05-05-2022	Rmc	M20	Vasanthi		148	Slab	2	3-6-22	29	20.0	470.0	20.9		
											20.0	460.0	20.4	20.4	
											20.0	450.0	20.0		
7819	05-05-2022	Rmc	M20	Vasanthi		149	Slab	2	3-6-22	29	20.0	465.0	20.7		
											20.0	455.0	20.2	20.2	
											20.0	445.0	19.8		
7820	05-05-2022	Rmc	M20	Vasanthi		150	Slab	2	3-6-22	29	20.0	460.0	20.4		
											20.0	460.0	20.4	20.3	
											20.0	450.0	20.0		
7821	05-05-2022	Rmc	M25	Ishaq		175	col	1	3-6-22	29	25.0	570.0	25.3		
											25.0	580.0	25.8	25.6	
											25.0	580.0	25.8		
7822	11-05-2022	Rmc	M20	Ishaq		172	plinth		8-6-22	28	20.0	455.0	20.2		
											20.0	455.0	20.2	20.2	
											20.0	455.0	20.2		
7823	11-05-2022	Rmc	M25	Ishaq		170	col	1	8-6-22	28	25.0	565.0	25.1		
											25.0	575.0	25.6	25.4	
											25.0	575.0	25.6		
7824	15-05-2022	Site Mix	M25	Vasanthi		148	col	3	13-6-22	29	25.0	560.0	24.9		
											25.0	570.0	25.3	25.2	
											25.0	570.0	25.3		
7825	15-05-2022	Site Mix	M25	Vasanthi		149	col	3	13-6-22	29	25.0	595.0	26.4		
											25.0	595.0	26.4	26.4	
											25.0	590.0	26.2		
7826	16-05-2022	Rmc	M20	Ishaq		171	plinth		13-6-22	28	20.0	460.0	20.4		
											20.0	460.0	20.4	20.3	
											20.0	450.0	20.0		
7827	16-05-2022	Rmc	M25	Ishaq		179	col	2	13-6-22	28	25.0	590.0	26.2		
											25.0	590.0	26.2	26.1	
											25.0	585.0	26.0		

7828	17-05-2022	Rmc	M25	Ishaq		178	col	2	14-6-22	28	25.0	585.0	26.0		
											25.0	585.0	26.0	25.8	
											25.0	570.0	25.3		
7829	18-05-2022	Rmc	M20	Ishaq		168	Slab	1	26-5-22	8	14.0	325.0	14.4		
											14.0	320.0	14.2	14.3	
											14.0	320.0	14.2		
7829	18-05-2022	Rmc	M20	Ishaq		168	Slab	1	16-6-22	29	20.0	465.0	20.7		
											20.0	465.0	20.7	20.6	
											20.0	460.0	20.4		
7830	18-05-2022	Rmc	M20	Ishaq		176	Slab	1	26-5-22	8	14.0	330.0	14.7		
											14.0	325.0	14.4	14.5	
											14.0	325.0	14.4		
7830	18-05-2022	Rmc	M20	Ishaq		176	Slab	1	16-6-22	29	20.0	465.0	20.7		
											20.0	460.0	20.4	20.4	
											20.0	455.0	20.2		
7831	20-05-2022	Rmc	M20	Scpl		158	Slab	2	26-5-22	6	14.0	340.0	15.1		
											14.0	325.0	14.4	14.7	
											14.0	325.0	14.4		
7831	20-05-2022	Rmc	M20	Scpl		158	Slab	2	18-6-22	29	20.0	470.0	20.9		
											20.0	460.0	20.4	20.4	
											20.0	450.0	20.0		
7832	20-05-2022	Rmc	M20	Scpl		155	Slab	3	26-5-22	6	14.0	345.0	15.3		
											14.0	330.0	14.7	14.8	
											14.0	325.0	14.4		
7832	20-05-2022	Rmc	M20	Scpl		155	Slab	3	18-6-22	29	20.0	475.0	21.1		
											20.0	465.0	20.7	20.7	
											20.0	455.0	20.2		
7833	20-05-2022	Rmc	M20	Scpl		154	Slab	3	26-5-22	6	14.0	340.0	15.1		
											14.0	325.0	14.4	14.5	
											14.0	315.0	14.0		
7833	20-05-2022	Rmc	M20	Scpl		154	Slab	3	18-6-22	29	20.0	470.0	20.9		
											20.0	455.0	20.2	20.3	
											20.0	445.0	19.8		
7834	20-05-2022	Rmc	M20	Scpl		153	Slab	3	26-5-22	6	14.0	345.0	15.3		
											14.0	335.0	14.9	14.8	
											14.0	320.0	14.2		
7834	20-05-2022	Rmc	M20	Scpl		153	Slab	3	18-6-22	29	20.0	475.0	21.1		
											20.0	450.0	20.0	20.6	
											20.0	465.0	20.7		
7835	22-05-2022	Rmc	M20	Ishaq		173	plinth		30-5-22	8	14.0	355.0	15.8		
											14.0	330.0	14.7	14.7	
											14.0	310.0	13.8		
7835	22-05-2022	Rmc	M20	Ishaq		173	plinth		20-6-22	29	20.0	480.0	21.3		
											20.0	455.0	20.2	20.7	
											20.0	460.0	20.4		
7836	22-05-2022	Rmc	M25	Ishaq		177	col	2	30-5-22	8	17.5	395.0	17.6		
											17.5	395.0	17.6	17.8	
											17.5	410.0	18.2		
7836	22-05-2022	Rmc	M25	Ishaq		177	col	2	20-6-22	29	25.0	595.0	26.4		
											25.0	595.0	26.4	26.3	
											25.0	585.0	26.0		
7837	24-05-2022	Rmc	M20	Ishaq		166	Slab	1	1-6-22	8	14.0	355.0	15.8		

[illegible]