QC - Concrete Cube Testing Report.

Company: MRMA(LLP)

Project: GMR

Report for Month: May - June = 2022.

Prepared By: QC Team

Date: 30-06-2022.

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
16181	11-05-2022	RMC	M20	Cemex Infra		H-block	Slab	2	10-6-22	30	20.0	475.0	21.1			
											20.0	450.0	20.0	20.5		
											20.0	460.0	20.4			