

QC - Concrete Cube Testing Report.															
Company:		Nrk-Biotech													
Project:		Nextopolis.													
Report for Month:		June - July (2022).													
Prepared By:		QC Team													
Date:		03-07-2022													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
23109	02-06-2022	RMC	M25	Ultra		Solvent store	Plinh		1-7-22	29	25.0	574.0	25.5		
											25.0	549.0	24.4	25.2	
											25.0	575.0	25.6		
23110	02-06-2022	RMC	M25	Ultra		Chemical store	Plinh		1-7-22	29	25.0	537.0	23.9		
											25.0	585.0	26.0	25.1	
											25.0	570.0	25.3		
23111	02-06-2022	RMC	M30	Ultra		1	Columns	2	1-7-22	29	30.0	652.0	29.0		
											30.0	747.0	33.2	30.1	
											30.0	630.0	28.0		
23112	04-06-2022	RMC	M30	Ultra		1	Columns	2	3-7-22	29	30.0	671.0	29.8		
											30.0	696.0	30.9	30.7	
											30.0	705.0	31.3		
23113	07-06-2022	RMC	M30	Ultra		1	Columns	2	5-7-22	28	30.0	753.0	33.5		
											30.0	610.0	27.1	30.4	
											30.0	690.0	30.7		
23114	14-06-2022	RMC	M25	Ultra		Solvent store	Columns	1	22-6-22	8	17.5	410.0	18.2		
											17.5	390.0	17.3	17.6	
											17.5	385.0	17.1		
23115	14-06-2022	RMC	M25	Ultra		Chemical store	Columns	1	22-6-22	8	17.5	412.0	18.3		
											17.5	405.0	18.0	18.5	
											17.5	430.0	19.1		