QC - Concrete Cube Testing Report.

Company:	MRGV
Project:	BRGV
Report for Month:	June - July = 2022..
Prepared By:	QC Team
Date:	30-07-2022

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
21025	31-05-2022	RMC	M20	Homeline		1	Slab	4	29-6-22	29	20.0	465.0	20.7			
											20.0	450.0	20.0	20.4		
											20.0	465.0	20.7			