

QC - Concrete Cube Testing Report.															
Company:		SOVLLP													
Project:		SOV													
Report for Month:		July - Aug = 2022.													
Prepared By:		QC Team													
Date:		04-08-2022													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
7874	13-06-2022	Rmc	M25	Scpl		146	col	1	21-6-22	8	17.5	395.0	17.6		
											17.5	395.0	17.6	17.8	
											17.5	410.0	18.2		
7874	13-06-2022	Rmc	M25	Scpl		146	col	1	12-7-22	29	25.0	585.0	26.0		
											25.0	595.0	26.4	26.3	
											25.0	595.0	26.4		
7875	29-07-2022	Rmc	M25	Ishaq		173	col	2	6-8-22	8	17.5	395.0	17.6		
											17.5	395.0	17.6	17.7	
											17.5	405.0	18.0		
7875	29-07-2022	Rmc	M25	Ishaq		173	col	2	26-8-22	28	25.0	580.0	25.8		
											25.0	595.0	26.4	26.2	
											25.0	595.0	26.4		
7876	29-07-2022	Rmc	M25	Ishaq		174	col	2	6-8-22	8	17.5	405.0	18.0		
											17.5	395.0	17.6	17.9	
											17.5	410.0	18.2		
7876	29-07-2022	Rmc	M25	Ishaq		174	col	2	26-8-22	28	25.0	580.0	25.8		
											25.0	590.0	26.2	26.1	
											25.0	590.0	26.2		
7877	02-08-2022	Rmc	M20	Ishaq		175	slab	2	10-8-22	8	14.0	310.0	13.8		
											14.0	328.0	14.6	14.1	
											14.0	315.0	14.0		
7877	02-08-2022	Rmc	M20	Ishaq		175	slab	2	31-8-22	29	20.0	465.0	20.7		
											20.0	488.0	21.7	21.5	
											20.0	495.0	22.0		
7878	02-08-2022	Rmc	M20	Ishaq		176	slab	2	10-8-22	8	14.0	355.0	15.8		
											14.0	335.0	14.9	14.9	
											14.0	315.0	14.0		
7878	02-08-2022	Rmc	M20	Ishaq		176	slab	2	31-8-22	29	20.0	475.0	21.1		
											20.0	465.0	20.7	20.7	
											20.0	455.0	20.2		
7879	02-08-2022	Rmc	M20	Ishaq		167	slab	2	10-8-22	8	14.0	330.0	14.7		
											14.0	325.0	14.4	14.5	
											14.0	325.0	14.4		
7879	02-08-2022	Rmc	M20	Ishaq		167	slab	2	31-8-22	29	20.0	470.0	20.9		
											20.0	460.0	20.4	20.4	
											20.0	450.0	20.0		
7880	02-08-2022	Rmc	M20	Ishaq		169	slab	2	10-8-22	8	14.0	335.0	14.9		
											14.0	330.0	14.7	14.7	
											14.0	330.0	14.7		
7880	02-08-2022	Rmc	M20	Ishaq		169	slab	2	31-8-22	29	20.0	475.0	21.1		
											20.0	465.0	20.7	20.7	
											20.0	460.0	20.4		

7881	02-08-2022	Rmc	M20	Ishaq		170	slab	2	10-8-22	8	14.0	340.0	15.1		
											14.0	335.0	14.9	15.1	
											14.0	345.0	15.3		
7881	02-08-2022	Rmc	M20	Ishaq		170	slab	2	31-8-22	29	20.0	485.0	21.6		
											20.0	475.0	21.1	21.3	
											20.0	475.0	21.1		
7882	04-08-2022	Rmc	M20	Cemex		146	slab	1	10-8-22	6	14.0	335.0	14.9		
											14.0	330.0	14.7	14.7	
											14.0	325.0	14.4		
7882	04-08-2022	Rmc	M20	Cemex		146	slab	1	31-8-22	27	20.0	480.0	21.3		
											20.0	470.0	20.9	20.9	
											20.0	460.0	20.4		
7883	04-08-2022	Rmc	M25	Vasanthi		147	col	1	10-8-22	6	17.5	405.0	18.0		
											17.5	395.0	17.6	17.9	
											17.5	405.0	18.0		
7883	04-08-2022	Rmc	M25	Vasanthi		147	col	1	31-8-22	27	25.0	575.0	25.6		
											25.0	565.0	25.1	25.1	
											25.0	555.0	24.7		
7884	04-08-2022	Rmc	M20	Vasanthi		151	slab	2	10-8-22	6	14.0	336.0	14.9		
											14.0	332.0	14.8	14.6	
											14.0	320.0	14.2		
7884	04-08-2022	Rmc	M20	Vasanthi		151	slab	2	31-8-22	27	20.0	475.0	21.1		
											20.0	465.0	20.7	20.7	
											20.0	460.0	20.4		
7885	04-08-2022	Site Mix	M25	Ishaq		177	col	3	10-8-22	6	17.5	390.0	17.3		
											17.5	395.0	17.6	17.6	
											17.5	405.0	18.0		
7885	04-08-2022	Site Mix	M25	Ishaq		177	col	3	31-8-22	27	25.0	585.0	26.0		
											25.0	585.0	26.0	25.8	
											25.0	570.0	25.3		
7886	05-08-2022	Site Mix	M25	Ishaq		168	col	3	14-8-22	9	17.5	410.0	18.2		
											17.5	410.0	18.2	17.9	
											17.5	390.0	17.3		
7886	05-08-2022	Site Mix	M25	Ishaq		168	col	3	4-9-22	30	25.0	585.0	26.0		
											25.0	590.0	26.2	25.9	
											25.0	570.0	25.3		

7887	06-08-2022	Rmc	M20	Ishaq		166	slab	2	14-8-22	8	14.0	320.0	14.2	
											14.0	315.0	14.0	14.2
											14.0	325.0	14.4	
7887	06-08-2022	Rmc	M20	Ishaq		166	slab	2	4-9-22	29	20.0	460.0	20.4	
											20.0	460.0	20.4	20.3
											20.0	450.0	20.0	
7888	07-08-2022	Site Mix	M25	Ishaq		167	col	3	14-8-22	7	17.5	425.0	18.9	
											17.5	420.0	18.7	18.8
											17.5	425.0	18.9	
7889	07-08-2022	Site Mix	M25	Ishaq		178	col	3	14-8-22	7	17.5	415.0	18.4	
											17.5	405.0	18.0	17.9
											17.5	390.0	17.3	
7890	08-08-2022	Site Mix	M25	Ishaq		179	col	3	14-8-22	6	17.5	410.0	18.2	
											17.5	405.0	18.0	17.8
											17.5	385.0	17.1	
7891	08-08-2022	Site Mix	M25	Ishaq		176	col	3	14-8-22	6	17.5	415.0	18.4	
											17.5	411.0	18.3	17.9
											17.5	385.0	17.1	
7892	09-08-2022	Site Mix	M25	Ishaq		170	col	3	17-8-22	8	17.5	420.0	18.7	
											17.5	415.0	18.4	18.1
											17.5	390.0	17.3	
7893	09-08-2022	Site Mix	M25	Ishaq		169	col	3	17-8-22	8	17.5	425.0	18.9	
											17.5	420.0	18.7	18.4
											17.5	395.0	17.6	
7894	09-08-2022	Site Mix	M25	Ishaq		175	col	3	17-8-22	8	17.5	415.0	18.4	
											17.5	395.0	17.6	17.7
											17.5	385.0	17.1	
7895	09-08-2022	Site Mix	M25	Ishaq		166	col	3	17-8-22	8	17.5	420.0	18.7	
											17.5	390.0	17.3	17.9
											17.5	395.0	17.6	
7896	10-08-2022	Site Mix	M25	Vasanthi		151	col	3	19-8-22	9	17.5	425.0	18.9	
											17.5	395.0	17.6	17.9
											17.5	385.0	17.1	
7897	10-08-2022	Rmc	M25	Cemex		146	col	3	19-8-22	9	17.5	435.0	19.3	
											17.5	400.0	17.8	18.1
											17.5	390.0	17.3	
7898	13-08-2022	Rmc	M20	Cemex		198	footings		19-8-22	6	14.0	325.0	14.4	
											14.0	330.0	14.7	14.7
											14.0	335.0	14.9	
7899	13-08-2022	Rmc	M20	Cemex		199	footings	1	19-8-22	6	14.0	345.0	15.3	
											14.0	330.0	14.7	14.8
											14.0	325.0	14.4	

QC - Concrete Cube Testing Report.															
Company:		SOVLLP													
Project:		SOV													
Report for Month:		July - Aug = 2022.													
Prepared By:		QC Team													
Date:		04-08-2022													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
7874	13-06-2022	Rmc	M25	Scpl		146	col	1	21-6-22	8	17.5	395.0	17.6		
											17.5	395.0	17.6	17.8	
											17.5	410.0	18.2		
7874	13-06-2022	Rmc	M25	Scpl		146	col	1	12-7-22	29	25.0	585.0	26.0		
											25.0	595.0	26.4	26.3	
											25.0	595.0	26.4		
7875	29-07-2022	Rmc	M25	Ishaq		173	col	2	6-8-22	8	17.5	395.0	17.6		
											17.5	395.0	17.6	17.7	
											17.5	405.0	18.0		
7875	29-07-2022	Rmc	M25	Ishaq		173	col	2	26-8-22	28	25.0	580.0	25.8		
											25.0	595.0	26.4	26.2	
											25.0	595.0	26.4		
7876	29-07-2022	Rmc	M25	Ishaq		174	col	2	6-8-22	8	17.5	405.0	18.0		
											17.5	395.0	17.6	17.9	
											17.5	410.0	18.2		
7876	29-07-2022	Rmc	M25	Ishaq		174	col	2	26-8-22	28	25.0	580.0	25.8		
											25.0	590.0	26.2	26.1	
											25.0	590.0	26.2		
7877	02-08-2022	Rmc	M20	Ishaq		175	slab	2	10-8-22	8	14.0	310.0	13.8		
											14.0	328.0	14.6	14.1	
											14.0	315.0	14.0		
7877	02-08-2022	Rmc	M20	Ishaq		175	slab	2	31-8-22	29	20.0	465.0	20.7		
											20.0	488.0	21.7	21.5	
											20.0	495.0	22.0		
7878	02-08-2022	Rmc	M20	Ishaq		176	slab	2	10-8-22	8	14.0	355.0	15.8		
											14.0	335.0	14.9	14.9	
											14.0	315.0	14.0		
7878	02-08-2022	Rmc	M20	Ishaq		176	slab	2	31-8-22	29	20.0	475.0	21.1		
											20.0	465.0	20.7	20.7	
											20.0	455.0	20.2		
7879	02-08-2022	Rmc	M20	Ishaq		167	slab	2	10-8-22	8	14.0	330.0	14.7		
											14.0	325.0	14.4	14.5	
											14.0	325.0	14.4		
7879	02-08-2022	Rmc	M20	Ishaq		167	slab	2	31-8-22	29	20.0	470.0	20.9		
											20.0	460.0	20.4	20.4	
											20.0	450.0	20.0		
7880	02-08-2022	Rmc	M20	Ishaq		169	slab	2	10-8-22	8	14.0	335.0	14.9		
											14.0	330.0	14.7	14.7	
											14.0	330.0	14.7		
7880	02-08-2022	Rmc	M20	Ishaq		169	slab	2	31-8-22	29	20.0	475.0	21.1		
											20.0	465.0	20.7	20.7	
											20.0	460.0	20.4		

7881	02-08-2022	Rmc	M20	Ishaq		170	slab	2	10-8-22	8	14.0	340.0	15.1		
											14.0	335.0	14.9	15.1	
											14.0	345.0	15.3		
7881	02-08-2022	Rmc	M20	Ishaq		170	slab	2	31-8-22	29	20.0	485.0	21.6		
											20.0	475.0	21.1	21.3	
											20.0	475.0	21.1		
7882	04-08-2022	Rmc	M20	Cemex		146	slab	1	10-8-22	6	14.0	335.0	14.9		
											14.0	330.0	14.7	14.7	
											14.0	325.0	14.4		
7882	04-08-2022	Rmc	M20	Cemex		146	slab	1	31-8-22	27	20.0	480.0	21.3		
											20.0	470.0	20.9	20.9	
											20.0	460.0	20.4		
7883	04-08-2022	Rmc	M25	Vasanthi		147	col	1	10-8-22	6	17.5	405.0	18.0		
											17.5	395.0	17.6	17.9	
											17.5	405.0	18.0		
7883	04-08-2022	Rmc	M25	Vasanthi		147	col	1	31-8-22	27	25.0	575.0	25.6		
											25.0	565.0	25.1	25.1	
											25.0	555.0	24.7		
7884	04-08-2022	Rmc	M20	Vasanthi		151	slab	2	10-8-22	6	14.0	336.0	14.9		
											14.0	332.0	14.8	14.6	
											14.0	320.0	14.2		
7884	04-08-2022	Rmc	M20	Vasanthi		151	slab	2	31-8-22	27	20.0	475.0	21.1		
											20.0	465.0	20.7	20.7	
											20.0	460.0	20.4		
7885	04-08-2022	Site Mix	M25	Ishaq		177	col	3	10-8-22	6	17.5	390.0	17.3		
											17.5	395.0	17.6	17.6	
											17.5	405.0	18.0		
7885	04-08-2022	Site Mix	M25	Ishaq		177	col	3	31-8-22	27	25.0	585.0	26.0		
											25.0	585.0	26.0	25.8	
											25.0	570.0	25.3		
7886	05-08-2022	Site Mix	M25	Ishaq		168	col	3	14-8-22	9	17.5	410.0	18.2		
											17.5	410.0	18.2	17.9	
											17.5	390.0	17.3		
7886	05-08-2022	Site Mix	M25	Ishaq		168	col	3	4-9-22	30	25.0	585.0	26.0		
											25.0	590.0	26.2	25.9	
											25.0	570.0	25.3		

7887	06-08-2022	Rmc	M20	Ishaq		166	slab	2	14-8-22	8	14.0	320.0	14.2	
											14.0	315.0	14.0	14.2
											14.0	325.0	14.4	
7887	06-08-2022	Rmc	M20	Ishaq		166	slab	2	4-9-22	29	20.0	460.0	20.4	
											20.0	460.0	20.4	20.3
											20.0	450.0	20.0	
7888	07-08-2022	Site Mix	M25	Ishaq		167	col	3	14-8-22	7	17.5	425.0	18.9	
											17.5	420.0	18.7	18.8
											17.5	425.0	18.9	
7889	07-08-2022	Site Mix	M25	Ishaq		178	col	3	14-8-22	7	17.5	415.0	18.4	
											17.5	405.0	18.0	17.9
											17.5	390.0	17.3	
7890	08-08-2022	Site Mix	M25	Ishaq		179	col	3	14-8-22	6	17.5	410.0	18.2	
											17.5	405.0	18.0	17.8
											17.5	385.0	17.1	
7891	08-08-2022	Site Mix	M25	Ishaq		176	col	3	14-8-22	6	17.5	415.0	18.4	
											17.5	411.0	18.3	17.9
											17.5	385.0	17.1	
7892	09-08-2022	Site Mix	M25	Ishaq		170	col	3	17-8-22	8	17.5	420.0	18.7	
											17.5	415.0	18.4	18.1
											17.5	390.0	17.3	
7893	09-08-2022	Site Mix	M25	Ishaq		169	col	3	17-8-22	8	17.5	425.0	18.9	
											17.5	420.0	18.7	18.4
											17.5	395.0	17.6	
7894	09-08-2022	Site Mix	M25	Ishaq		175	col	3	17-8-22	8	17.5	415.0	18.4	
											17.5	395.0	17.6	17.7
											17.5	385.0	17.1	
7895	09-08-2022	Site Mix	M25	Ishaq		166	col	3	17-8-22	8	17.5	420.0	18.7	
											17.5	390.0	17.3	17.9
											17.5	395.0	17.6	
7896	10-08-2022	Site Mix	M25	Vasanthi		151	col	3	19-8-22	9	17.5	425.0	18.9	
											17.5	395.0	17.6	17.9
											17.5	385.0	17.1	
7897	10-08-2022	Rmc	M25	Cemex		146	col	3	19-8-22	9	17.5	435.0	19.3	
											17.5	400.0	17.8	18.1
											17.5	390.0	17.3	
7898	13-08-2022	Rmc	M20	Cemex		198	footings		19-8-22	6	14.0	325.0	14.4	
											14.0	330.0	14.7	14.7
											14.0	335.0	14.9	
7899	13-08-2022	Rmc	M20	Cemex		199	footings	1	19-8-22	6	14.0	345.0	15.3	
											14.0	330.0	14.7	14.8
											14.0	325.0	14.4	