

QC - Concrete Cube Testing Report.															
Company:	GVDC														
Project:	Genopolis														
Report for Month:	Aug - Sept = 2022.														
Prepared By:	QC Team														
Date:	02-10-2022														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bangalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
20168	03-08-2022	RMC	M25	homeline infra		119 OHT-	Top Slab	Top Slab	1-9-22	29	25.0	565.0	25.1		
											25.0	575.0	25.6		
											25.0	590.0	26.2		
20169	03-08-2022	RMC	M25	homeline infra		119 OHT-	Slab	Top Slab	1-9-22	29	25.0	575.0	25.6		
											25.0	585.0	26.0	26.1	
											25.0	605.0	26.9		
20170	18-08-2022	RMC	M25	rdc		Chemical std	Col	3	17-9-22	30	25.0	580.0	25.8		
											25.0	590.0	26.2	26.3	
											25.0	605.0	26.9		
20171	04-09-2022	RMC	M35	Ishaq		Central lobb	Slab	3	12-9-22	8	23.5	545.0	24.2		
											23.5	530.0	23.6	23.9	
											23.5	535.0	23.8		
20172	09-09-2022	RMC	M35	Ishaq		119	Col	4	17-9-22	8	23.5	550.0	24.4		
											23.5	535.0	23.8	24.1	
											23.5	540.0	24.0		

QC - Concrete Cube Testing Report															
Company:		GVDC													
Project:		Genopolis													
Report for Month:		July - Aug = 2022													
Prepared By:		QC Team													
Date:		07-09-2022													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
20168	03-08-2022	RMC	M25	homeline infra		119 OHT-1	Top Slab	Top Slab	12-8-22	9	17.5	435.0	19.3		
											17.5	420.0	18.7		
											17.5	390.0	17.3	18.4	
20169	03-08-2022	RMC	M25	homeline infra		119 OHT-2	Slab	Top Slab	12-8-22	9	17.5	425.0	18.9		
											17.5	415.0	18.4	18.3	
											17.5	395.0	17.6		
20170	18-08-2022	RMC	M25	rdc		Chemical store	Col	3	26-8-22	8	17.5	410.0	18.2		
											17.5	395.0	17.6	18.1	
											17.5	415.0	18.4		