

QC - Concrete Cube Testing Report.																			
Company:		SOVLLP																	
Project:		SOV																	
Report for Month:		May - June = 2022.																	
Prepared By:		QC Team																	
Date:		06-10-2022																	
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-new tons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks				
7888	07-08-2022	Site Mix	M25	Ishaq		167	col	3	5-9-22	29	25.0	585.0	26.0						
											25.0	595.0	26.4	26.3					
											25.0	595.0	26.4						
7889	07-08-2022	Site Mix	M25	Ishaq		178	col	3	5-9-22	29	25.0	580.0	25.8						
											25.0	590.0	26.2	26.1					
											25.0	590.0	26.2						
7890	08-08-2022	Site Mix	M25	Ishaq		179	col	3	5-9-22	28	25.0	575.0	25.6						
											25.0	585.0	26.0	25.9					
											25.0	585.0	26.0						
7891	08-08-2022	Site Mix	M25	Ishaq		176	col	3	5-9-22	28	25.0	580.0	25.8						
											25.0	590.0	26.2	26.1					
											25.0	595.0	26.4						
7892	09-08-2022	Site Mix	M25	Ishaq		170	col	3	8-9-22	30	25.0	595.0	26.4						
											25.0	605.0	26.9	26.6					
											25.0	595.0	26.4						
7893	09-08-2022	Site Mix	M25	Ishaq		169	col	3	8-9-22	30	25.0	590.0	26.2						
											25.0	605.0	26.9	26.4					
											25.0	585.0	26.0						
7894	09-08-2022	Site Mix	M25	Ishaq		175	col	3	8-9-22	30	25.0	600.0	26.7						
											25.0	610.0	27.1	26.6					
											25.0	585.0	26.0						
7895	09-08-2022	Site Mix	M25	Ishaq		166	col	3	8-9-22	30	25.0	570.0	25.3						
											25.0	580.0	25.8	25.6					
											25.0	580.0	25.8						
7896	10-08-2022	Site Mix	M25	Vasanthi		151	col	3	8-9-22	29	25.0	575.0	25.6						
											25.0	595.0	26.4	26.1					
											25.0	595.0	26.4						
7897	10-08-2022	Rmc	M25	Cemex		146	col	3	8-9-22	29	25.0	595.0	26.4						
											25.0	615.0	27.3	26.9					
											25.0	609.0	27.1						
7898	13-08-2022	Rmc	M20	Cemex		198	Footings		11-9-22	29	20.0	485.0	21.6						
											20.0	495.0	22.0	22.1					
											20.0	510.0	22.7						
7899	13-08-2022	Rmc	M20	Cemex		199	Footings		11-9-22	29	20.0	480.0	21.3						
											20.0	490.0	21.8	21.9					
											20.0	505.0	22.4						