

Internal memo no. 903/35/A
Annexure - B
RMC pour report

Company/ firm:	GV Research Centers Pvt Ltd.	Block No.:	Towards 4545, atrium upper basement floor cc purpose.
Project:	Imopolis	Flat / Villa no.:	
Supplier:	RDC Concrete Private limited	Slab no.:	
Requisition nos.:	206148	A. Estimated quantity:	420M3
PO nos.:	20220803001	B. Requisition quantity:	420M3
Sign of Security	Sign of Admin	Sign of Project Manger	62M3
	<i>Poojesh.</i>	<i>Sudevi</i>	<i>Mayur</i>
		D. Difference (C-A)	358M3

Details of RMC pour

Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Time of pour	Quantity poured	Dc No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1.	22.08.2022	07:43	08:36	10:09	07	S3573	16800	16660	-			
2.	22.08.2022	08:05	09:00	10:54	07	S3574	16800	16850	-			
3.	22.08.2022	08:24	10:14	11:39	07	S3575	16800	16770	-			
4.	22.08.2022	10:04	11:18	12:28	07	S3577	16800	16440	360			
5.	22.08.2022	10:20	12:32	13:19	07	S3578	16800	17090	-			
6.	22.08.2022	11:02	13:23	14:21	07	S3580	16800	16700	-			
7.	22.08.2022	12:41	13:42	14:55	07	S3582	16800	16750	-			
8.	22.08.2022	15:09	15:57	16:29	07	S3585	16800	16980	-			
9.	22.08.2022	17:09	17:54	18:25	06	S3588	14400	14630	-			
10.												
11.												
Total:					62M3		148800	148870	360			
Remarks	As per Po quantity 420M3 but consumed only 62M3											

Note: 1. Report to be sent on a daily basis to purchase@modiproperties.com and report-audit@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at site