Internal memo no. 903/35/A
Annexure - B
RMC pour report

Company/ firm:	GV Research Centers Pvt Ltd.		Block No.:	Towards 4545 Slab-5 Purpose.
Project:	Innopolis		Flat / Villa no.:	
Supplier:	SL RMC PLANT		Slab no.:	
Requisition nos.:	206256		A. Estimated quantity:	790M3
PO nos.:	20220910003		B. Requisition quantity:	790M3
Sign of Security	Sign of Admin	Sign of Project Manger	C. Actual quantity poured	105M3
Rajesh			D. Difference (C-A)	685M3

Details of RMC pour

Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Time of pour	Quantity poured	Dc No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1.	26.09.2022	23:31	00:21	00:38	07	4647	16800	16820	-			
2.	26.09.2022	23:48	00:48	01:24	07	4648	16800	16730	-			
3.	26.09.2022	23:58	01:05	02:18	07	4649	16800	14240	2560			
4.	26.09.2022	00:10	01:17	02:36	08	4228	19200	19710	-			
5.	26.09.2022	00:52	01:34	02:40	07	4650	16800	16220	580			
6.	26.09.2022	01:06	01:52	02:32	08	4229	19200	19640	-			
7.	26.09.2022	01:17	02:21	03:44	07	4652	16800	16790	-			
8.	26.09.2022	01:03	02:27	02:57	06	4651	14400	13530	8770			
9.	26.09.2022	01:33	02:41	03:08	07	4653	16800	16770	-			
10.	26.09.2022	01:43	02:47	03:49	06	4654	14400	14170	-			
11.	26.09.2022	02:05	02:54	03:25	07	4655	16800	16860	-			
12.	26.09.2022	03:23	04:19	04:42	07	4656	16800	16990	-			
13.	26.09.2022	03:35	04:30	05:34	07	4657	16800	16950	-			
14.	26.09.2022	03:50	04:44	05:18	07	4658	16800	16410	390			
15.	26.09.2022	04:55	05:59	06:43	07	4659	16800	16450	350			
16.	26.09.2022											

17.	26.09.2022											
Total:					105M3		252000	248280	12650			
Remarks	As per Po quantity 790M3 but consumed only 105M3											

Note: 1. Report to be sent on a daily basis to purchase@modiproperties.com and report-audit@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weighment slips + pour reports + test reports + photographs at sit