

Internal memo no. 903/35/A
Annexure - B
RMC pour report

Company/ firm:	GV Research Centers Pvt Ltd.	Block No.:	South side road touch up and transform work purpose
Project:	Imnopolis	Flat / Villa no.:	
Supplier:	SL RMC PLANT	Slab no.:	
Requisition nos.:	206383	A. Estimated quantity:	20M3
PO nos.:	20221031002	B. Requisition quantity:	20M3
Sign of Security	Sign of Admin	Sign of Project Manger	08M3
	<i>Sudevi</i>	<i>mev. @alway</i>	D. Difference (C-A)
			12M3

Details of RMC pour

Sl. No	Date	Time of dispatch h from RMC plant	Time of receipt at site	Time of pour	Quantity poured	Dc No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1.	10.11.2022	11:32	12:15	12:42	08	4951	19200	20310	-			
2.												
3.												
Total:					08M3		19200	20310				
Remarks	As per po quantity 20M3 but consumed only 08M3											

Note: 1. Report to be sent on a daily basis to purchase@rmpcproperties.com and report@rmpcproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for once PO. 5. Weight all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at site.