QC - Concrete Cube Testing Report.

Company: MRGV

Project: BRGV

Report for Month: Sep - Oct = 2022.

Prepared By: QC Team

Date: 25-10-2022

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
21031	11-09-2022	Rmc	M25	HL Infra		1	Col	1	10-10-22	29	25.0	585.0	26.0		
											25.0	580.0	25.8	25.7	
											25.0	570.0	25.3		