QC - Concrete Cube Testing Report.

Company: GVDC

Project: GENOPOLIS

Report for Month: Sep - Oct = 2022.

Prepared By: QC Team

Date: 25-10-2022

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
20171	04-09-2022	Rmc	M35	Ishaq		Central	Slab	3	3-10-22	29	35.0	785.0	34.9		
											35.0	810.0	36.0	35.4	
											35.0	795.0	35.3		
20172	09-09-2022	Rmc	M35	Ishaq		119	Col	4	8-10-22	29	35.0	795.0	35.3		
											35.0	815.0	36.2	35.6	
											35.0	790.0	35.1		
20173	24-09-2022	Rmc	M35	Ishaq		119	Col	4	3-10-22	9	23.5	550.0	24.4		
											23.5	535.0	23.8	24.1	
											23.5	545.0	24.2		
20173	24-09-2022	Rmc	M35	Ishaq		119	Col	4	23-10-22	29	35.0	800.0	35.6		
											35.0	810.0	36.0	35.6	
											35.0	795.0	35.3		