Internal memo no. 903/35/A Annexure - B RMC pour report

center	Block No.:	Towards Chemical slab pu	
	Flat / Villa no.:	-	
	Slab no.:	-04	
	A. Estimated quantity:	6 cub meter	
	B. Requisition quantity:	6 cub meter	
Sign of Project Manger	C. Actual quantity poured	4 cub meter	
111	D. Difference (C-A)	-2 cub meter	
•		Flat / Villa no.: Slab no.: A. Estimated quantity: B. Requisition quantity: C. Actual quantity poured	

Details of RMC pour

		PV.										7 day	20
2	SI. No	Date	Time of dispatch from RMC	Time of receipt at site	Time of pour	Quantity poured	Dc No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	for shortfall in Rs.	cube test	cube test strength in kN/m2
1 T	1.	18.11.2022	plant 14:45 PM	15:50	18:00	4 m3	5416	9,600	9,430				
	Total	:	1 nos			4 m3		9,600	9,430				
	Rema	arks											

28 days

Note: 1. Report to be sent on a daily basis to <u>purchase@modiproperties.com</u> and <u>report-audit@modiproperties.com</u>. 2. Report must be prepared during pour and not later: 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles: 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weighment slips + pour reports + test reports + photographs at site.