QC - Concrete Cube Testing Report.

Company: GVRC

Project: Innopolis

Report for Month: Oct - Nov = 2022

Prepared By: QC Team

Date: 20-12-2022

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
14207	28-11-2022	RMC	M25	SL Infra		4545	Slab	5	6-12-22	8	17.5	399.0	17.7		
											17.5	395.0	17.6	18.1	
											17.5	425.0	18.9		