

QC - Concrete Cube Testing Report.																
Company:		SOV (LLP)														
Project:		SOV - III														
Report for Month:		Nov - Dec = 2022..														
Prepared By:		QC Team														
Date:		29-12-2022														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
7932	24-11-2022	RMC	M20	Cemex Infra		193	Plinth		23-12-22	29	20.0	475.0	21.1			
											20.0	465.0	20.7	21.1		
											20.0	485.0	21.6			
7933	24-11-2022	RMC	M20	Cemex Infra		194	Plinth		23-12-22	29	20.0	470.0	20.9			
											20.0	460.0	20.4	20.8		
											20.0	475.0	21.1			
7934	30-11-2022	RMC	M20	Cemex Infra		195	Plinth		8-12-22	8	14.0	350.0	15.6			
											14.0	345.0	15.3	15.1		
											14.0	325.0	14.4			
7934	30-11-2022	RMC	M20	Cemex Infra		195	Plinth		29-12-22	29	20.0	470.0	20.9			
											20.0	460.0	20.4	20.8		
											20.0	475.0	21.1			
7935	30-11-2022	RMC	M20	Cemex Infra		196	Plinth		8-12-22	8	14.0	355.0	15.8			
											14.0	350.0	15.6	15.4		
											14.0	335.0	14.9			
7935	30-11-2022	RMC	M20	Cemex Infra		196	Plinth		29-12-22	29	20.0	480.0	21.3			
											20.0	460.0	20.4	20.5		
											20.0	445.0	19.8			
7936	03-12-2022	RMC	M20	Cemex Infra		189	footings		10-12-22	7	14.0	335.0	14.9			
											14.0	330.0	14.7	14.5		
											14.0	315.0	14.0			

[illegible]