

Internal memo no. 903/35/A
Annexure - B
RMC pour report

Company/ firm:	Modi Reality Mallapur LLP	Block No.:	Driveway footings beams and site miscellaneous purpose.
Project:	Gulmohar Residency	Flat / Villa no.:	-
Supplier:	CEMEX INFRA	Slab no.:	-
Requisition nos.:	208729	A. Estimated quantity:	20M3 (M25)
PO nos.:	20230112002	B. Requisition quantity:	20M3
Sign of Security	Sign of Admin	C. Actual quantity poured	3M3
	24/01/23	D. Difference (C-A)	17M3

Details of RMC pour

Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Time of pour	Quantity poured	Dc No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1.	19.01.23	15:06	15:15	15:30	3m3	1863	7200	7090	-110			
2.												
3.												
4.												
5.												
6.												
7.												
8.												
9.												
10.												
Total:					3m3		7200	7090	-110			
Remarks	Po not to be closed.											

Note: 1. Report to be sent on a daily basis to purchase@modiproperties.com and report-audit@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at sit

CEMEX INFRA

No. 312, Rampally (Vill), Keesara (Mdl)
Medchal (Dist), Hyderabad - 501301.
Ph. 9848 210 686 / 9133 333 5839
Email: cemexinfra9@gmail.com

**CEMEX INFRA****READY MIX CONCRETE****GSTIN : 36AANFC3197R1ZJ****DELIVERY CHALLAN**

PONo/2023012002

Bul-6

Customer Name: MPLLP			D.C. No: 1863		Date: 19/Jan/23
Delivery Site: N F C			Truck No: TS 08 UE 5548		Mode: DUMP
S.No:	GRADE	Qty	Units	Cum. Qty	Remarks
1	M25	3.00	Cum	3.00	GOOD

Other Documents Enclosed:

1)

2)

Note: No alterations will be accepted without
supplier & Customer Signatures alongwith reasons

Received above material in good condition

Customer Signature

For Office use only

- Driver Name:

BHANU

- Signature:

INWARD
MODI REALTY MALLAPUR LLP
Ward No. **11095** DL **19/1/23**

MRN NO

Sign...

for Cemex Infra

Authorised Signatory