QC - Concrete Cube Testing Report.

Company: GVRC

Project: Innopolis

Report for Month: Dec - Jan = 2022 - 2023.

Prepared By: QC Team

Date: 04-02-2023

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
14208	02-12-2022	RMC	M25	KN Infra		3600 A&C	Footings		1-1-23	30	25.0	599.0	26.6		
											25.0	595.0	26.4	25.9	
											25.0	555.0	24.7		