QC - Concrete Cube Testing Report.																
Company:		GVRC														
Project:		Innopolis														
Report for Month:		(Jan - Feb) = - 2023														
Prepared By:		QC Team														
Date:		02-03-2023														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
14209	17-01-2023	RMC	M25	SL Rmc plant		4545	Slab	Top slab	25-1-23	8	17.5	415.0	18.4			
											17.5	410.0	18.2	18.1		
											17.5	394.0	17.5			
14209	17-01-2023	RMC	M25	SL Rmc plant		4545	Slab	Top slab	15-2-23	29	25.0	595.0	26.4			
											25.0	598.0	26.6	26.3		
											25.0	585.0	26.0			