QC - Concrete Cube Testing Report.																
Company:		Nrk-Biotech														
Project:		Nextopolis.														
Report for Month:		Mar - Apr = (2023).														
Prepared By:		QC Team														
Date:		25-04-2023														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
23127	11-03-2023	RMC	M30	SL Rmc plant		Main block	COL	4	10-4-23	30	30.0	690.0	30.7			
											30.0	705.0	31.3	31.2		
											30.0	710.0	31.6			