

DELIVERY CHALLAN

Plot No. 26, S.S. Villas,
Markandeya Nagar, Kapra,
Hyderabad,
Telangana - 500 062.

D.C. No.: **137**

Date: 15/5/2023

To, G.V. One
M/s.

PO: 2023-0510-009

Vehicle No.: TS08UG 4743

Truck capacity.

S.No.	Grade	PARTICULARS	Qty.	Cum.	Value
1	M30	7.26: - 11:00	7M ³	7M ³	Devil.

IM. CODEX

2023051

SCAN ID

5011

Inward No: 511

Dr: 15/5/23

Received by: [Signature]

Sign: [Signature]

CRESCENT LABS PVT LTD

For **SL RMC PLANT**


Hand at

Receiver's Signature

Authorised Signatory

Internal memo no. 903/35/A Annexure - B

RMC pour report

Company/ firm:	Crescentia Labs Pvt. Ltd.		Block No:	south block retaining wall and staircase concreting.	
Project:	GV ONE		Flat / Villa no:		
Supplier:	R6 Infra		Slab no:		
Requisition nos:	20230510008		A. Estimated quantity:	200 cum	
PO nos.:	20230510009		B. Requisition quantity:	200 cum	
Sign of Security	Sign of Admin	Sign of Project Manger	C. Actual quantity poured	31 cum	
			D. Difference (C-A)	169 cum	

Details of RMC pour

Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Time of pour	Quantity poured (Cum)	De No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1	15.05.23	10:52	11:57	12:10	7	137	16,800	16,700	100			
			Total		7		16,800	16,700	100			

Remarks balance quantity will be used later

Note: 1. Report to be sent on a daily basis to purchase@modiproperties.com and report-audit@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weighment slips + pour reports + test reports + photographs at site.

MRN. No. 20230515011