

From: Addl. Assistant Engineer
(Electrical)
Mushenabad Section
Distribution VI, City-II,
A.P.S.E.B., HYDERABAD

To,
The Accounts Officer
G.R.C. Yunt Compound
Hyderabad.

Dr. no. AAE/m/001/02/d.no 299/95 dt. 28.1.95

Sir,

Sub.- Furnishing of Periodical Readings of
A/c no F. 10795 m/s. Dishrajpet Castings
1-7-105% Muzumbar - Requesting - Reg.

I am here with furnishing the periodical
Readings of A/c F. 10795 with below particulars
are available as per this office records.

Mt. no.	750 5441	SA	CT Ratio	50/5	MA - 10
19. 1. 95	- 1 -				000 96
19. 12. 94	- 4 -				000 28
19. 11. 94	- 11 -				14 684
20. 10. 94	- 11 -				14 684

The above service meter is changed
on 3.12.94 due to meter burnt out, with below
particulars.

Removed Mt. no.	800 3472	10A	100/10 CT	MA - 10
Fixed Mt. no.	750 5441	SA	50/5 CT	MA - 10

The above service is inspected by
me and found that, at the time of inspection
there is no machinery in the Consumer premises,
and the supply is being utilized for Motor
workshop purpose only.

Hence it is requested to issue
an average bills during the months 11/94 and 12/94
as 680 units / month based on 1/95 consumption.

// COUNCIL SIGNED //

yours faithfully,

Bluehddy 31/1/95
Asst. Divisional Engineer
(Electrical)
Distribution VI, City-II,
A.P.S.E.B., HYDERABAD



addl Assistant Engineer
(Electrical)
Mushenabad Section
Distribution VI, City-II,
A.P.S.E.B., HYDERABAD