

DELIVERY CHALLAN



R6 Infra

READY MIX CONCRETE AND BRICKS

Plot No. 15, S.S. Villas,
Markandeya Nagar, Kapra,
Hyderabad, Telangana - 500 062.

D.C. No. : **1277**

Date : 20/05/2023

To,
M/s. GU ONE Hyderabad.

Vehicle No. : TS07A 4988 - Samil

S.No.	Grade	PARTICULARS	Qty.	Cum.	Value
01	cm30	20230510009 MRN NO: 20230522022	3m ³	3m ³	2400000

Receiver's Signature

INWARD

Inward No: 1322	Dt: 20/5/23
MRN No:	Dt:
Received By:	

CRESCENTIA LABS PVT LTD

For **R6 Infra**

Authorised Signatory

Company/ firm:	Crescentia Labs Pvt. Ltd.		Block No:	central lobby shear wall concreting
Project:	GV ONE		Flat / Villa no:	
Supplier:	R6 Infra		Slab no:	
Requisition nos:	20230510008		A. Estimated quantity:	200 cum
PO nos.:	20230510009		B. Requisition quantity:	200 cum
Sign of Security	Sign of Admin	Sign of Project Manger	C. Actual quantity poured	52 cum
			D. Difference (C-A)	148 cum

Details of RMC pour

Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Time of pour	Quantity poured (Cum)	Dc No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1	22.05.23	10:10	11:02	11:13	3	1277	7,200	7,170	30			
				Total	3		7,200	7,170	30			

Remarks balance quantity will be used later

Note: 1. Report to be sent on a daily basis to purchase@modiproperties.com and report-audit@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at site.

MRN. NO: 20230522022