QC - Concrete Cube Testing Report.																
Company:		MRM (LLP)														
Project:		GMR														
Report for Month:		Apr - May = 2023														
Prepared By:		QC Team														
Date:		06-06-2023														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
16207	08-05-2023	RMC	M25	Cemex Infra		Driveway	Slab	2	16-5-23	8	17.5	405.0	18.0			
											17.5	395.0	17.6	17.7		
											17.5	398.0	17.7			