

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1	QC - Concrete Cube Testing Report.																
2	Company:		SOV (LLP)														
3	Project:		SOV - III														
4	Report for Month:		(Apr - May) = 2023.														
5	Prepared By:		QC Team														
6	Date:		02-06-2023														
7																	
8																	
9	S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
10	7001	11-03-2023	RMC	M25	Cemex Infra		190	COL	1	20-3-23	9	17.5	410.0	18.2			
11												17.5	415.0	18.4	18.3		
12												17.5	410.0	18.2			
13																	
14	7001	11-03-2023	RMC	M25	Cemex Infra		190	COL	1	10-4-23	30	25.0	575.0	25.6			
15												25.0	580.0	25.8	25.9		
16												25.0	595.0	26.4			
17																	
18	7002	13-03-2023	RMC	M20	Ishaq		186	Slab	2	20-3-23	7	14.0	320.0	14.2			
19												14.0	315.0	14.0	14.4		
20												14.0	335.0	14.9			
21																	
22	7002	13-03-2023	RMC	M20	Ishaq		186	Slab	2	10-4-23	28	20.0	458.0	20.4			
23												20.0	448.0	19.9	20.4		
24												20.0	468.0	20.8			
25																	
26	7003	13-03-2023	RMC	M20	Ishaq		187	Slab	2	20-3-23	7	14.0	350.0	15.6			
27												14.0	345.0	15.3	15.5		
28												14.0	350.0	15.6			
29																	
30	7003	13-03-2023	RMC	M20	Ishaq		187	Slab	2	10-4-23	28	20.0	470.0	20.9			
31												20.0	460.0	20.4	20.9		
32												20.0	480.0	21.3			
33																	
34	7004	13-03-2023	RMC	M20	Ishaq		188	Slab	2	20-3-23	7	14.0	345.0	15.3			
35												14.0	340.0	15.1	15.3		
36												14.0	345.0	15.3			
37																	
38	7004	13-03-2023	RMC	M20	Ishaq		188	Slab	2	10-4-23	28	20.0	465.0	20.7			
39												20.0	455.0	20.2	20.7		

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
40												20.0	475.0	21.1			
41																	
42	7005	14-03-2023	RMC	M25	Cemex Infra		191	COL	1	22-3-23	8	17.5	398.0	17.7			
43												17.5	410.0	18.2	17.9		
44												17.5	400.0	17.8			
45																	
46	7005	14-03-2023	RMC	M25	Cemex Infra		191	COL	1	12-4-23	29	25.0	585.0	26.0			
47												25.0	565.0	25.1	25.4		
48												25.0	565.0	25.1			
49																	
50	7006	14-03-2023	RMC	M25	Cemex Infra		192	COL	1	22-3-23	8	17.5	400.0	17.8			
51												17.5	405.0	18.0	17.9		
52												17.5	405.0	18.0			
53																	
54	7006	14-03-2023	RMC	M25	Cemex Infra		192	COL	1	12-4-23	29	25.0	575.0	25.6			
55												25.0	585.0	26.0	25.9		
56												25.0	585.0	26.0			
57																	
58	7007	14-03-2023	RMC	M20	Cemex Infra		136	footings		22-3-23	8	14.0	340.0	15.1			
59												14.0	325.0	14.4	14.8		
60												14.0	335.0	14.9			
61																	
62	7007	14-03-2023	RMC	M20	Cemex Infra		136	footings		12-4-23	29	20.0	470.0	20.9			
63												20.0	455.0	20.2	20.6		
64												20.0	465.0	20.7			
65																	
66	7008	21-03-2023	RMC	M25	Rekha pande		199	COL	2	30-3-23	9	17.5	415.0	18.4			
67												17.5	395.0	17.6	18.1		
68												17.5	410.0	18.2			
69																	
70	7008	21-03-2023	RMC	M25	Rekha pande		199	COL	2	20-4-23	30	25.0	595.0	26.4			
71												25.0	595.0	26.4	26.5		
72												25.0	601.0	26.7			
73																	
74	7009	21-03-2023	RMC	M25	Rekha pande		198	COL	2	30-3-23	9	17.5	405.0	18.0			
75												17.5	420.0	18.7	18.1		
76												17.5	395.0	17.6			
77																	
78	7009	21-03-2023	RMC	M25	Rekha pande		198	COL	2	20-4-23	30	25.0	590.0	26.2			
79												25.0	590.0	26.2	26.2		
80												25.0	590.0	26.2			
81																	
82	7010	24-03-2023	RMC	M25	Rekha pande		197	COL	2	30-3-23	6	17.5	390.0	17.3			

[illegible]

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
126	7015	30-03-2023	RMC	M25	Ishaq		205	COL	2	29-4-23	30	25.0	580.0	25.8			
127												25.0	575.0	25.6	25.5		
128												25.0	565.0	25.1			
129																	
130	7016	31-03-2023	RMC	M20	Cemex Infra		200	plinth		7-4-23	7	14.0	329.0	14.6			
131												14.0	325.0	14.4	14.6		
132												14.0	330.0	14.7			
133																	
134	7016	31-03-2023	RMC	M20	Cemex Infra		200	plinth		29-4-23	29	20.0	445.0	19.8			
135												20.0	460.0	20.4	20.3		
136												20.0	465.0	20.7			
137																	
138	7017	05-04-2023	RMC	M20	Ishaq		191	Slab	1	14-4-23	9	14.0	345.0	15.3			
139												14.0	325.0	14.4	14.7		
140												14.0	325.0	14.4			
141																	
142	7017	05-04-2023	RMC	M20	Ishaq		191	Slab	1	5-5-23	30	20.0	470.0	20.9			
143												20.0	488.0	21.7	21.1		
144												20.0	465.0	20.7			
145																	
146	7018	18-04-2023	RMC	M20	Rekha pande		197	Slab	2	27-4-23	9	14.0	340.0	15.1			
147												14.0	335.0	14.9	15.3		
148												14.0	355.0	15.8			
149																	
150	7018	18-04-2023	RMC	M20	Rekha pande		197	Slab	2	18-5-23	30	20.0	450.0	20.0			
151												20.0	455.0	20.2	20.7		
152												20.0	495.0	22.0			
153																	
154	7019	18-04-2023	RMC	M20	Rekha pande		198	Slab	2	27-4-23	9	14.0	320.0	14.2			
155												14.0	315.0	14.0	14.4		
156												14.0	335.0	14.9			
157																	
158	7019	18-04-2023	RMC	M20	Rekha pande		198	Slab	2	18-5-23	30	20.0	470.0	20.9			
159												20.0	460.0	20.4	20.9		
160												20.0	480.0	21.3			
161																	
162	7020	18-04-2023	RMC	M20	Rekha pande		199	Slab	2	27-4-23	9	14.0	340.0	15.1			
163												14.0	335.0	14.9	15.1		
164												14.0	345.0	15.3			
165																	
166	7020	18-04-2023	RMC	M20	Rekha pande		199	Slab	2	18-5-23	30	20.0	475.0	21.1			
167												20.0	465.0	20.7	20.8		
168												20.0	465.0	20.7			

[illegible]